



DER INTEGRATION – EPCOR'S EXPERIENCE IN EDMONTON


Darren McCrank, P.Eng.

Director, Ontario Operations
Ontario Region

EPCOR


The Theoretical Impacts of DG and ES

Classic DG Example:



Courtesy Sandia National Laboratories

With Battery ES




Courtesy Sandia National Laboratories



EDTI's Study with the University of Alberta

- Simulation-based technical study - 2014-2018
- Three-way funding EDTI – U of A - NSERC
- 'Realistic-as-possible' approach:
 - City of Edmonton conditions
 - 39/289 EDTI power system distribution circuit models
 - Capabilities of market-available equipment
 - *Stochastic* approach (Monte Carlo)
- Broadly examine impacts of three classes of *customer-owned* DER:
 - DG: Distributed Generation (e.g. Solar PV)
 - ES: Energy Storage (e.g. Batteries)
 - EV: Electric Vehicle (e.g. Charging)
- Examine effects to the distribution system





Key Findings Distributed Generation


- IF customer PV systems are in-line with Alberta microgen regulation, ~80% of EDTI circuits should only experience outlier problems
- Circuits with voltage outliers still have decent capacity to integrate PV

Energy Storage

- All ES modelled with co-located PV
- Two behaviours modelled
 - Self-consumption
 - On peak discharge, off peak charge
- Min load when generating, peak load when charging – worst case




Energy Storage (from the perspective of the ES)




Impacts to a Distribution Circuit – TOU Scenario

Under-voltage, as a result of ES Charging



Over-voltage, as a result of excess PV generation






Key Findings Energy Storage

- Simulated self-consumption scenario had less impact than incentive scenario
- Mismatch to site demand and co-located generation could lead to over voltage and under voltage impacts – hard to predict
- Potential to exacerbate and or alleviate strain on distribution infrastructure
- More study is needed

The Impacts of Electric Vehicles

- What makes EV load any different?



Residential sites in Edmonton:

- 100 or 150A Service
- @ 240V, 20-80A per EV

Variables:

- Base load?
- Where will cars plug in?
- When will they plug in?
- How long will they charge?
- What is the maximum load?



Residential Transformers

DFO's provide **capacity** to non-instantaneous (i.e. system average) **peak load**

Per 37.5kVA Transformer:


- Per house: Average, peak load 2-3kW
- Transformer average peak: 24-36kW
 - >20,000 installed 37.5kVAs in Edmonton

EV Charging Levels:

- Per EV: Charging Demand 3.2-19.2kW
 - Average ~ 7.2kW
- Concurrent charging: two Tesla's at 19.2kW -> 38.4kW

Transformer Load With & Without an EV


- A real example from EDTI's system:



Impacts to Planning & Forecasting

- DFO's provide **capacity** to non-instantaneous (i.e. system average) **peak load**

Peak demand (MW), 15kV residential circuit



EV Charging Levels:

- This circuit peaks at 5.6MW
- 2.5MW of remaining capacity which is the equivalent to:
 - 132 EVs @ 19.2kW or
 - 793 EVs @ 3.2kW
- 5,500+ customers on circuit

Key Findings


- Unprecedented demand - 2x to 10x addition of load compared to a house
- Granularity is needed – all the way down to the transformer
- Charging demand is what matters
 - Only 1 EV can overload standard service transformer
 - A small number of EVs could lead to circuit overloads


EPCOR



Navigating the EV Challenge

- Fundamental mismatch between existing capacity and future demand
- Will require additional distribution infrastructure
- Potential ways of deferring, delaying, reducing capital investment
 - Smart chargers?
 - Utility visibility / control (DERMS)?
 - Incentives?
 - New rules? New Legislation?
 - Co-located ES, to buffer the power demand?
 - Demand-side technologies?
- For each of these, must consider
 - Impact to customers
 - Complexity of deployment
 - Extent of mitigating effect on utility cost of service





THANK YOU

