

Attachment A

Maximum Cumulative Generation Capacity from Net Metered Generators that the Distributor Must Allow to be Connected EB-2005-0447

Amendments to the Distribution System Code (the "Code")

1. Section 1.7 of the Code is amended by adding the following paragraph at the end of the section:

Section 6.7 of the Code and the amendment to section 4.2 of the "Micro-Embedded Load Displacement Generation Facility Connection Agreement" in Appendix E of the Code, made by the Board on February 1, 2006 come into force on February 10, 2006.

2. Section 6 of the Code is amended by adding a new section 6.7 as follows:

6.7 Net Metered Generators

6.7.1 In this section 6.7:

"eligible generator" in respect of a distributor means a customer of a distributor that meets the criteria set out in section 7(1) of the Net Metering Regulation;

"net metered generator" means an eligible generator to whom net metering has been made available by a distributor; and

"Net Metering Regulation" means the *Net Metering Regulation*, O. Reg. 541/05.

- 6.7.2 A distributor shall, upon request, make net metering available to eligible generators in its licensed service area in accordance with the Net Metering Regulation, on a first-come first-served basis, unless the cumulative generation capacity from net metered generators in its licensed service area equals one percent of the distributor's annual maximum peak load for the distributor's licensed service area, averaged over three years, as determined by the Board from time to time.

- 6.7.3 A distributor shall bill a net metered generator on a net metering basis in accordance with the Net Metering Regulation provided that the net metered generator meets the requirements of section 2(2) of the Net Metering Regulation.
- 6.7.4 A distributor may, upon request, make net metering available to additional eligible generators in its licensed service area and may bill them on a net metering basis when the cumulative maximum generation capacity from net metered generators in its licensed service area exceeds one percent of the distributor's annual maximum peak load for the distributor's licensed service area, averaged over three years, as referred to in section 6.7.2.
- 6.7.5 A distributor shall, in the manner and time specified by the Board, file with the Board the total rated maximum output capacity of generation facilities in its licensed service area to which net metering has been made available as of:
- February 10, 2006; and
 - such later dates as are determined by the Board.
3. Section 4.2 of the "Micro-Embedded Load Displacement Generation Facility Connection Agreement" in Appendix E of the Code is amended by adding the following phrase to the end of that section:

unless you are, at the relevant time, a net metered generator