

APPENDIX E

Information in a Connection Agreement with a Generator

**APPENDIX E -
INFORMATION IN A CONNECTION AGREEMENT WITH A GENERATOR**

A Connection Agreement between a distributor and an embedded generator shall contain specific terms and conditions relating to connection and access to the distributor's distribution system. Such terms and conditions include, but are not limited to, the following:

1. Requirements for the inspection and testing of equipment
2. Requirements for maintenance of the equipment.
3. Worker protection and safety considerations, and measures to protect the public and the environment.
4. Requirements for testing protection systems associated with the connection.
5. Requirements for reporting any change affecting connected equipment of the configuration of this equipment
6. Protocols for the provision of load forecast or forecasts of information
7. Terms and conditions for disconnection and reconnection, including as to the responsibility for the payment of costs associated with reconnection
8. Requirements for coordinating maintenance and operations.
9. Duration and termination conditions
10. Details of the connection point, including the ownership of the facility
11. Connection service charges and payment conditions
12. Requirements for reporting changes affecting access to metering, monitoring and telemetry equipment
13. Circumstances that would require re-negotiation of the Connection Agreement.
14. Exchange procedures for information requirements..
15. Communication and operating protocols between distributor and generator for routine day-to day operating matters and under emergency conditions.
16. Access to connection facilities.
17. Assignment of Controlling Authority
18. Work Protection