APPENDIX 2

 $\frac{\textbf{TRANSMISSION SYSTEM CONNECTION POINT PERFORMANCE}}{\textbf{STANDARDS}}$

Deleted: Amended Proposal (June 2, 2005)

Formatted: Font: 10 pt

<u>Transmission System Code</u>, Appendix 2

APPENDIX 2

$\frac{\textbf{TRANSMISSION SYSTEM CONNECTION POINT PERFORMANCE}}{\underline{\textbf{STANDARDS}}}$

| Ref | Item | Requirement Transmission voltages of 500 kV, 230 kV and 115 kV shall be maintained in accordance with the Market Rules. Voltages below 50 kV shall be maintained in accordance with CSA 235 | | | | |
|-----|----------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------|---------------------------|----------------------------------------|--|
| 1 | Voltage variations | | | | | |
| 2 | | Nominal Voltage (kV) | Maximum 3 (kA) | Maximum SLG Fault (kA) | | |
| | Fault Levels ¹ | 500 | 80 (usually limited to 63 kA) | | 80 (usually limited to 63 kA) | |
| | | 230 | 63 | | 80 (usually limited to 63 kA) | |
| | | 115 | 50 | | 50 | |
| | Higher values may | 44 | 20 | | 19 (usually limited to 8 kA) | |
| | exist for short times during switching | 27.6 (4-wire) | 17 | | 12 | |
| | | 27.6 (3-wire) | 17 | | 0.45 | |
| | | 13.8 | 21 | | 10 | |
| 3 | Circuit Breaker | Nominal Voltage (kV) | Rated Interrupting Time (cycles) | | Automatic Reclose Time (Seconds) | |
| | Interrupting and | 500 | ≤2 | | 10-15 | |
| | Automatic Single | 230 | ≤3 | | 5-15 | |
| | Shot Reclose Time | 115 | ≤5 | | 3-6 | |
| | | < 50 | ≤8 | | varies significantly | |
| 4 | Unbalance | Voltage unbalance is limited to 2% (CAN/CSA E 1000 2-2-97) | | | | |
| 5 | Flicker | Voltage flicker shall be limited as tabulated. | | | | |
| | | Magnitude (%) Limit | | Limit | | |
| | | 1 | | 3 per second | 1 | |
| | | <u> </u> | | 20 per minute | | |
| | | | | 45 per hour | | |
| | | 3.0 | 4 per day | | | |
| | | A higher flicker may be acceptable for infrequent starts. | | | | |
| 6 | Switching Surges | All equipment shall be able to withstand capacitor switching surges that transiently increase voltage to twice normal levels. | | | | |

 $^{^{1}\,}$ Maximum fault values referred to in this Appendix are symmetrical fault values.

Deleted: Amended Proposal (June 2, 2005)

Formatted: Font: 10 pt

| 7 | Voltage Harmonics | Voltage harmonics shall respect limitations described in Table 11.1 Voltage Distortion Limits IEEE Std 519-1992 | |
|---|---------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------|--|
| 8 | Current Harmonics | Current harmonics shall respect limitations described in Tables 10.3 to 10.5 Current Distortion Limits IEEE Std 519-1992. | |
| 9 | Telephone Interference | I.T. Product balanced (in phase conductors) shall be less than 5,000 amperes I.T. Product residual (in ground return path) shall be less than 250 amperes | |

Deleted: Amended Proposal (June 2, 2005)

Formatted: Font: 10 pt