

**Average Age of Plant  
Selected Electricity Distributors - 2006**

<b>Distributor</b>	<b>Gross PP&amp;E \$Million</b>	<b>Depreciation Expense \$Million</b>	<b>Implied Average Age of PP&amp;E Years</b>
Barrie Hydro	223	8	26.9
Brant County	24	1	24.7
Brantford	68	3	26.6
Chatham-Kent	60	3	20.2
Enersource	735	38	19.4
Halton Hills	38	2	20.0
Horizon	551	20	28.0
Hydro One Networks	6,020	251	24.0
Hydro Ottawa	886	33	26.8
Kitchener Wilmot	248	9	29.2
Milton	69	2	28.8
Orangeville	26	1	29.2
Parry Sound	10	0	26.3
Powerstream	839	29	29.4
Toronto Hydro	3,352	125	26.9
Waterloo North	167	6	28.5
<b>Total of Selected</b>	<b>13,316</b>	<b>529</b>	<b>25.2</b>
<b>All Ontario Distributors Total</b>	<b>17,135</b>	<b>676</b>	<b>25.3</b>

*Source: 2006 Yearbook of Electricity Distributors, Ontario Energy Board*

**Inflation Escalator**

Average age of plant 19 years	27.6%
Average age of plant 25.3 years	49.1%
Average age of plant 29 years	72.8%