



ONTARIO ENERGY BOARD

Transmission System Code

Last Revised December 18, 2018

(Originally Issued on July 14, 2000)

TABLE OF CONTENTS

1. PURPOSE	4
2. DEFINITIONS	5
3. APPLICATION AND INTERPRETATION.....	14
3A. SCREENING CRITERIA FOR ENABLER FACILITIES	17
3B. RELIABILITY AND INTEGRITY OF TRANSMISSION SYSTEM	18
3C. REGIONAL PLANNING.....	19
4. STANDARDS OF BUSINESS PRACTICE AND CONDUCT	25
4.1 GENERAL REQUIREMENTS	25
4.2 TRANSMISSION SERVICE CHARGES	26
4.3 FACILITIES STANDARDS	26
4.4 OPERATIONAL STANDARDS AND REPORTING PROTOCOL	28
4.5 PERFORMANCE STANDARDS	28
4.6 COMPLIANCE OF FACILITIES WITH STANDARDS	30
4.7 CONFIDENTIALITY	31
5. REQUIREMENTS FOR OPERATIONS AND MAINTENANCE.....	33
5.1 DAY-TO-DAY OPERATIONS.....	33
5.2 FORCED OUTAGES	33
5.3 SCHEDULING OF PLANNED WORK.....	33
5.4 EMERGENCY OPERATIONS.....	34
6. CUSTOMER CONNECTIONS.....	35
6.1 GENERAL REQUIREMENTS	35
6.2 AVAILABLE CAPACITY	39

6.3	COST RESPONSIBILITY FOR NEW AND MODIFIED CONNECTIONS.....	45
6.4	CUSTOMER IMPACT ASSESSMENTS	52
6.5	ECONOMIC EVALUATION OF NEW AND MODIFIED CONNECTIONS.....	54
6.6	CONTESTABILITY	59
6.7	REPLACEMENT AND RELOCATION OF EXISTING CONNECTION FACILITIES	61
6.8	OBLIGATIONS BETWEEN NEIGHBOURING ONTARIO TRANSMITTERS.....	62
6.9	RECORD KEEPING AND REPORTING REQUIREMENTS	63
6.10	RECONNECTION	63
7.	COMPLIANCE, INSPECTION, TESTING AND MONITORING.....	65
7.1	REQUIREMENTS	65
8.	GENERAL TECHNICAL REQUIREMENTS	66
8.1	INTENTIONALLY LEFT BLANK	66
8.2	PROTECTION AND CONTROL.....	66
8.3	INSULATION COORDINATION.....	68
8.4	GROUNDING.....	68
9.	TECHNICAL REQUIREMENTS FOR TAPPED TRANSFORMER STATIONS SUPPLYING LOAD	69
9.1	SUPPLY CONSIDERATIONS	69
9.2	PROTECTION REQUIREMENTS	69
10.	PROTECTION SYSTEM REQUIREMENTS	71
10.1	TELECOMMUNICATIONS.....	71
10.2	TEST SCHEDULE FOR RELAYING COMMUNICATION CHANNELS	72
10.3	VERIFICATION AND MAINTENANCE PRACTICES	72
10.4	FUNCTIONAL TESTS AND PERIODIC VERIFICATION.....	72

10.5 FAILURE PROTECTION FOR HIGH VOLTAGE INTERRUPTING DEVICES73

10.6 INSTRUMENT TRANSFORMERS.....74

10.7 BATTERY BANKS AND DIRECT CURRENT SUPPLY74

11. EMBEDDED GENERATION AND BYPASS COMPENSATION 76

11.1 EMBEDDED GENERATION76

11.2 BYPASS COMPENSATION77

12. DISPUTE RESOLUTION 80

12.1 OBLIGATION TO INCLUDE IN PROCEDURES80

13. COMING INTO FORCE 82

APPENDICES

APPENDIX 1: VERSION A - FORM OF CONNECTION AGREEMENT FOR LOAD CUSTOMERS

APPENDIX 1: VERSION B - FORM OF CONNECTION AGREEMENT FOR GENERATOR CUSTOMERS

APPENDIX 2: TRANSMISSION SYSTEM CONNECTION POINT PERFORMANCE STANDARDS

APPENDIX 3: INFORMATION TO BE MADE AVAILABLE TO CUSTOMERS BY TRANSMITTERS

APPENDIX 4: CUSTOMER FINANCIAL RISK CLASSIFICATION

APPENDIX 5: METHODOLOGY AND ASSUMPTIONS FOR ECONOMIC EVALUATIONS

1. PURPOSE

1.0.1 The purpose of this Transmission System Code (the “Code”) is to set out:

- (a) the minimum conditions that a transmitter shall meet in designing, constructing, managing, maintaining and operating its transmission system;
- (b) the rules governing a transmitter's obligation to connect customers to its transmission system, and to provide transmission service to its customers;
- (c) the obligations between a transmitter and its customers and between a transmitter and its neighbouring Ontario transmitters;
- (d) the rules governing the economic evaluation of transmission system connections and expansions;
- (e) the minimum standards for facilities connected to a transmission system; and
- (f) through the connection agreement set out in Appendix 1, the obligations of a customer to the transmitter to whose transmission system the customer's facilities are connected.

2. DEFINITIONS

- 2.0.1 "Act" means the *Ontario Energy Board Act, 1998*, S.O.1998, c.15, Schedule B, and includes all regulations made thereunder;
- 2.0.2 "assigned capacity" means, in relation to a load customer and a connection facility, the capacity determined in accordance with section 6.2.2;
- 2.0.3 "available capacity" means, at a given time, the capacity on a connection facility that is not at that time assigned to a load customer;
- 2.0.4 "Board" means the Ontario Energy Board;
- 2.0.5 "bus" means a common current carrying element which allows the connection of other elements to that common element;
- 2.0.6 "business day" means any day that is not a Saturday, a Sunday or a legal holiday in the Province of Ontario;
- 2.0.7 "CIA" means customer impact assessment;
- 2.0.8 "circuit breaker" means a system element that interrupts the flow of electricity upon receiving a trip signal and includes, where applicable, any associated current transformer and the bus section between the breaker bushing and its current transformer;
- 2.0.9 "Code revision date" means the date on which this Code comes into effect as specified in section 13.0.1;
- 2.0.10 "come into service" means, in relation to a facility, the time at which the facility becomes connected to a transmission system and energized following commissioning of the facility;
- 2.0.11 "connect" means to form a direct physical link between a transmitter's transmission facilities and a customer's facilities or a neighbouring Ontario transmitter's facilities;
- 2.0.12 "connection agreement" means an agreement entered into by a transmitter and a customer setting out terms and conditions pertaining to connection of the

customer's facilities to the transmitter's transmission system and the provision of transmission services in relation to those customer facilities, but does not include a "connection and cost recovery agreement" or similar agreement entered into in relation to the construction of new or modified facilities where it is contemplated that a connection agreement will thereafter be entered into;

2.0.13 "connection facilities" means line connection facilities and transformation connection facilities that connect a transmitter's transmission system with the facilities of another person, and includes an enabler facility but excludes any line referred to in section 3.0.14(a) and any station referred to in section 3.0.14(b);

2.0.14 "connection point" means a point of connection between a transmitter's transmission facilities and a customer's facilities and, in the case of an enabler facility, means each point of connection between the enabler facility and any customer facility connected to the enabler facility;

2.0.15 "connection service" in relation to a transmitter has the meaning given in the transmitter's Rate Order;

2.0.16 "consumer" means a person using, for their own consumption, electricity that they did not generate and whose facilities are connected to a transmission system;

2.0.17 "contracted capacity" means, in relation to a load customer and a connection facility, the capacity determined in accordance with section 6.2.3;

2.0.18 "customer" means a generator, consumer, distributor or unlicensed transmitter whose facilities are connected to or are intended to be connected to a transmission system;

2.0.19 "customer facilities" means any and all equipment, elements, and facilities of any kind whatsoever owned by a customer that are relevant to a connection;

2.0.20 "de-energized" means a state at which the stored potential energy of an isolated piece of equipment has been discharged. Electrical equipment is considered de-energized when its electrical energy has been discharged through connection to an effective ground potential. Mechanical equipment is considered de-energized when hazards due to temperature, pressure, chemical substances, gases, radiation, and motion have been minimized or, where practical, eliminated by measures including the following: (i) operation of valves, gates and dampers;

(ii) opening of pipes or equipment to the atmosphere; (iii) purging, ventilating, or cooling; (iv) applying brakes and blocking motion; and (v) discharging loaded springs;

2.0.21 "delivery point" has the same meaning as "connection point";

2.0.22 "distribute" with respect to electricity means to convey electricity at voltages of 50 kV or less;

2.0.23 "distributor" means a person who owns or operates a distribution system;

2.0.24 "distribution system" means a system for distributing electricity, and includes any structures, equipment or other things used for that purpose;

2.0.25 "electricity" means electrical energy as measured in kilowatt hours;

2.0.26 "Electricity Act" means the *Electricity Act, 1998*, S.O.1998, c.15, Schedule A, and includes all regulations made thereunder;

2.0.27 "element" means any electrical device that has at least one terminal that is operated at greater than 50 kV and that may be connected to other electrical devices, and is usually associated with a generator, transformer, transmission circuit, circuit breaker, HVDC pole, series or shunt compensating device or bus section;

2.0.28 "emergency" means any abnormal condition that requires automatic or immediate manual action to prevent or limit loss of a licensed transmitter's transmission facilities or loss of the supply of electricity or energy that could adversely affect: (a) the reliability of the licensed transmitter's transmission system, (b) the integrity of customer facilities or of the licensed transmitter's transmission facilities, or (c) public safety, property or the environment;

2.0.28A "enabler facility" means a line connection facility or a transformation connection facility that is or will be constructed, owned and operated by a transmitter and to which two or more generation facilities that are included in a renewable resource cluster are connected or intend to connect to convey energy into a transmitter's transmission system, where any of the following apply: (a) the connection facility is identified as an "enabler facility" and the associated renewable resource cluster is identified as such in an integrated power system plan that has been approved under Part II.2 of the Electricity Act or in a Board-approved plan filed

with the Board by a transmitter pursuant to the deemed condition of the transmitter's licence referred to in paragraph 2 of subsection 70(2.1) of the Act; (b) the associated renewable resource cluster is the subject of a direction issued by the Minister to the Ontario Power Authority under section 25.32 of the Electricity Act on or after October 20, 2009 and the Board, on the advice of the Ontario Power Authority, has determined that a connection facility is required; or (c) the OPA has provided the Board with written advice identifying the associated renewable resource cluster as one for which an enabler facility would be desirable, and the Board has determined that a connection facility is required and that the connection facility satisfies the screening criteria set out in section 3A.

- 2.0.29 "facilities" means transmission facilities, a neighbouring Ontario transmitter's facilities or customer facilities, as the context requires, and includes any structures, lines, transformers, breakers, disconnect switches, buses, voltage/current transformers, protection systems, telecommunications systems, cables and any other auxiliary equipment used for the purpose of conveying electricity;
- 2.0.30 "fault" means an event arising from the failure of facilities, including a short circuit, an open circuit, or an intermittent connection;
- 2.0.31 "forced outage" means the automatic or manual limitation of service owing to de-rating or limitation of facilities, or the unavailability of facilities as a result of actual or potential failure of those facilities or of any other facilities related to them;
- 2.0.32 "generator customer" means a customer who owns or operates a generation facility;
- 2.0.33 "good utility practice" means any of the practices, methods and acts engaged in or approved by a significant portion of the electrical utility industry in North America during the relevant time period, or any of the practices, methods and acts which, in the exercise of reasonable judgment in light of the facts known at the time the decision was made, could have been expected to accomplish the desired result at a reasonable cost consistent with good business practices, reliability, safety and expedition. Good utility practice is not intended to be limited to optimum practices, methods or acts to the exclusion of all others, but rather to include all practices, methods or acts generally accepted in North America;

- 2.0.34 "harmonic" means a sinusoidal component of a periodic wave or quantity having a frequency that is an integral multiple of the fundamental frequency (for example, a component whose frequency is twice the fundamental frequency is called a second harmonic);
- 2.0.35 "IESO" means the Independent Electricity System Operator continued under the Electricity Act;
- 2.0.36 "isolate" means to separate facilities from any source of dynamic energy;
- 2.0.37 "isolating device" means a device used to separate facilities from any source of dynamic energy;
- 2.0.38 "licence" means a licence issued under Part V of the Act;
- 2.0.39 "line connection" means radial lines that do not, under normal operating conditions, connect network stations and whose sole purpose is to serve one or more persons;
- 2.0.40 "load customer" means a customer who owns or operates a facility other than a generation facility or a transmission system;
- 2.0.41 "load shedding" means the deliberate disconnection of the load of a customer from a transmission system or a distribution system (either manually or automatically) in response to an emergency in order to maintain the integrity of the transmission system or distribution system and to minimize overall outages to customer facilities;
- 2.0.42 "maintenance" includes such routine maintenance, troubleshooting, repairs, changes, modifications and other activities as may be required for the safe and efficient operation of facilities;
- 2.0.43 "Market Rules" means the rules made under section 32 of the Electricity Act;
- 2.0.44 "neighbouring Ontario transmitter" in relation to a licensed transmitter (the "first transmitter") means another licensed transmitter whose transmission system is located in Ontario and is connected to that of the first transmitter or that seeks to have its transmission system located in Ontario connected to that of the first transmitter, as the context requires;

2.0.45 "network facilities" means those facilities, other than connection facilities, that form part of a transmission system that are shared by all users, comprised of network stations and the transmission lines connecting them, and has the extended meaning given to it in section 3.0.14;

2.0.45A "network station" means:

(a) any station with one or more of the following:

- i. a 500 kV element, including a 500/230 kV or a 500/115 kV autotransformer;
- ii. a 230 kV or 115 kV element that switches lines that normally operate in parallel with lines that connect transmission stations containing 500 kV elements;
- iii. a 345 kV, 230 kV or 115 kV element that switches a 345 kV, 230 kV or 115 kV line that connects with the transmission system of a neighbouring Ontario transmitter or with a transmission system outside Ontario, including a 345/230 kV autotransformer; or
- iv. a 345 kV, 230 kV or 115 kV element that switches a 345 kV, 230 kV or 115 kV line that connects interconnection circuits to any network station referred to in any of (i) to (iii) above; and

(b) any station that the Board has determined should be treated as a network facility in or through a Decision, Order or Decision and Order issued before August 26, 2013, and has the extended meaning given to it in section 3.0.14;

2.0.46 "NERC" means the North American Electric Reliability Corporation;

2.0.47 "net book value" means the net book value used by the Board for rate-making purposes;

2.047A "OPA" means the Independent Electricity System Operator or successor company;

2.0.48 "outage" means the removal of facilities from service, unavailability for connection of facilities, temporary de-rating, restriction of use or reduction in the performance of facilities for any reason, including to permit the inspection, testing, maintenance or repair of facilities;

- 2.0.49 "planned outage" means an outage that is planned or intentional and that is scheduled to occur at a pre-selected time, usually for the purpose of permitting construction, preventative maintenance or repair;
- 2.0.50 "promptly" means performed in an expeditious manner and without undue delay, using due diligence, and with the intent of completing a required act or task as quickly as practicable;
- 2.0.51 "protection system" means equipment that detects faults or abnormal conditions and takes appropriate corrective action to isolate the faulted element;
- 2.0.52 "protective relay" means an electrical device that detects a fault or abnormal condition on a transmission system or a distribution system and that is designed to respond to abnormal variations in input conditions and to cause prescribed contact operation or similar abrupt changes in associated electric control circuits which, in turn, if prescribed parameters are met, initiate the operation of a system element (such as a circuit breaker) to disconnect a faulty element (such as a transformer);
- 2.0.53 "Rate Order" means an order made by the Board under the Act, and in effect at the relevant time, that, among other things, establishes the rates that may be charged by a transmitter for transmission service;
- 2.0.54 "reliability", in relation to electricity service, means the ability to deliver electricity in accordance with all applicable reliability standards and in the amount desired;
- 2.0.55 "reliability organization" means NERC, the Northeast Power Coordinating Council, and the IESO;
- 2.0.56 "reliability standards" means the criteria, standards and requirements relating to reliability set forth in this Code and, where relevant, as established by applicable reliability organizations;
- 2.0.57 "renewable generation" means a generation facility that generates electricity using a renewable energy source as defined in the Electricity Act;
- 2.0.57A "renewable resource cluster" means a geographic area where resources suitable for renewable generation are present and where the renewable generation facilities are not, or are not expected to be, owned or controlled by the same person and that is identified as such in: (a) an integrated power system

plan approved under Part II.2 of the Electricity Act or a Board-approved plan filed with the Board by a transmitter pursuant to the deemed condition of the transmitter's licence referred to in paragraph 2 of subsection 70(2.1) of the Act; (b) a direction issued by the Minister to the Ontario Power Authority under section 25.32 of the Electricity Act; or (c) written advice from the OPA to the Board;

- 2.0.58 "single contingency" means a single event, usually involving the loss of one or more elements, that affects a transmission system at least momentarily;
- 2.0.59 "site" means the land, buildings and other structures on, in or around which facilities are located;
- 2.0.60 "transformation connection" means transformation facilities, tapped off a transmission system, that step down voltages from transmission levels to distribution levels (i.e. from more than 50 kV to 50 kV or less) in order to supply the facilities of a person;
- 2.0.61 "transmission facilities" means facilities owned by a transmitter that form part of or all the transmission system owned by that transmitter;
- 2.0.62 "transmission service" means a service provided by a transmitter to a customer as specified in the transmitter's Rate Order, and includes Network Service, Line Connection Service, Transformation Connection Service or such other transmission service as may be described in such Rate Order;
- 2.0.63 "transmission system" means a system for transmitting electricity and includes any structures, equipment or other things used for that purpose;
- 2.0.64 "transmit" with respect to electricity means to convey electricity at voltages of more than 50 kV;
- 2.0.65 "transmitter" means a person who owns or operates a transmission system;
- 2.0.66 "unlicensed transmitter" means a person who owns or operates a transmission system and that is exempt from the requirement to hold a licence under section 57(b) of the Act by virtue of a regulation made under the Act or of the application of section 84 of the Act; and

2.0.67 "work" includes design, installation, construction, commissioning, removal, inspection, testing, undertaking of repairs or undertaking of maintenance.

3. APPLICATION AND INTERPRETATION

- 3.0.1 All appendices attached to this Code form part of it. Unless otherwise defined in this Code, words and phrases shall have the meaning ascribed to them in the Act or the Electricity Act. Headings are for convenience only and shall not affect the interpretation of this Code. Words importing the singular include the plural and vice versa. Words importing a gender include any gender. Words importing a person include (i) an individual, (ii) a company, sole proprietorship, partnership, trust, joint venture, association, corporation or other private or public body corporate; and (iii) any government, government agency or body, regulatory agency or body or other body politic or collegiate. A reference to a person includes that person's successors and permitted assigns. A reference to a body, whether statutory or not, that ceases to exist or whose functions are transferred to another body is a reference to the body that replaces it or that substantially succeeds to its powers or functions. Where a word or phrase is defined in this Code, the Act or the Electricity Act, other parts of speech and grammatical forms of the word or phrase have a corresponding meaning. A reference to a document (including a statutory instrument) or a provision of a document includes any amendment or supplement to, or any replacement of, that document or that provision. The expression "including" means including without limitation.
- 3.0.2 A reference in this Code to "dedicated" connection facilities means that such facilities are constructed initially for the sole use of a single customer, but shall not be interpreted to mean that such facilities cannot thereafter be used by any other customer if they are owned by a licensed transmitter at the relevant time.
- 3.0.3 A reference in this Code to:
- (a) "existing load" in relation to a load customer and a connection facility, shall at any point in time be equal to the customer's assigned capacity on that connection facility at that time; and
 - (b) "new load", in relation to a load customer and a connection facility, shall at any point in time:
 - i. if the customer has contracted capacity, be equal to the load that exceeds the customer's contracted capacity at that time; or

- ii. in any other case, be equal to the load that exceeds the customer's existing load as determined under section 3.0.3(a).

3.0.4 Except when an emergency is anticipated or is occurring, if the time for doing any act or omitting to do any act under this Code expires on a day that is not a business day, the act may be done or may be omitted to be done on the next day that is a business day.

3.0.5 Except to the extent provided in a transmitter's licence, another code issued by the Board or an order of the Board, this Code applies to all licensed transmitters and to all transactions and interactions between a licensed transmitter and its customers and between a licensed transmitter and its neighbouring Ontario transmitters.

3.0.6 Subject to sections 3.0.5 and 3.0.9, a transmitter shall not:

- (a) enforce any provision of any agreement that is contrary to or inconsistent with this Code;
- (b) apply any provision of any agreement in a manner that is contrary to or inconsistent with this Code; or
- (c) require any person to enter into an agreement that contains a provision that is contrary to or inconsistent with this Code or to otherwise agree to terms and conditions that are contrary to or inconsistent with this Code.

This section 3.0.6 applies to an agreement regardless of whether the agreement was entered into before the Code revision date. Nothing in this section 3.0.6 shall affect the continued validity of a provision of any agreement entered into before the Code revision date under which the parties agreed to realign their relationship or amend the agreement in a manner consistent with this Code.

3.0.7 Subject to sections 3.0.5, 3.0.8 and 3.0.9, all connection agreements executed prior to the Code revision date in furtherance of the requirement set out in section 2.1.1 of the Transmission System Code as it existed prior to the Code revision date are, as of the Code revision date, deemed to be amended to conform to the applicable version of the connection agreement set out in Appendix 1. The relationship between the parties shall thereafter be governed by the applicable version of the connection agreement set out in Appendix 1.

- 3.0.8 Where an agreement entered into before the Code revision date contains provisions that were negotiated between the parties and that are not contrary to or inconsistent with this Code, those provisions shall remain in effect and must be honoured by the parties accordingly.
- 3.0.9 Where an economic evaluation was carried out prior to the Code revision date, such economic evaluation shall for the purposes of the application of this Code be deemed to have been carried out under this Code and shall, together with the associated load forecast, apply for the purposes of this Code.
- 3.0.10 Sections 3.0.6 to 3.0.9 are without prejudice to the resolution of any dispute between a transmitter and a customer that may have arisen prior to the Code revision date.
- 3.0.11 A provision in an agreement entered into before the Code revision date is not contrary to or inconsistent with this Code simply by reason of the fact that this Code does not expressly contemplate such provision or is silent on the matter.
- 3.0.12 To the extent of any inconsistency or conflict between them, a Rate Order and the Affiliate Relationships Code for Electricity Transmitters and Distributors prevail over this Code.
- 3.0.13 Any matter under this Code requiring a determination by the Board may be determined without a hearing or through an oral, written or electronic hearing, at the Board's discretion.
- 3.0.14 Subject to section 3.0.15:
- (a) a "network facility" includes any line that forms part of the physical path between:
 - i. two network stations; or
 - ii. a network station and the transmission system of a neighbouring Ontario transmitter or a transmission system outside Ontario,such that electricity can be transmitted along the entire path under some operating conditions, which may or may not reflect normal operating conditions; and

- (b) a “network station” includes any station with one or more of the following:
 - i. an element that is greater than 500 kV;
 - ii. an autotransformer that steps down voltage from a higher transmission level to a lower transmission level;
 - iii. a transmission switchyard to which all of the following are connected:
 - A. one or more generation facilities with a minimum aggregate installed rated capacity of 250 MW ;
 - B. one or more load facilities with a minimum aggregate load of 150 MW; and
 - C. a minimum of four transmission circuits.

3.0.15 Section 3.0.14 only applies where the line referred to in section 3.0.14(a) or the station referred to in section 3.0.14(b):

- (a) commences to be constructed on or after August 26, 2013; or
- (b) is expanded or reinforced for the purposes of increasing its capacity, and the expansion or reinforcement (or the expanded or reinforced line or station) commences to be constructed on or after August 26, 2013, regardless of when the line or station was originally placed into service.

3A. SCREENING CRITERIA FOR ENABLER FACILITIES

3A.1 The following are the screening criteria that must be satisfied by a connection facility in order to qualify as an enabler facility where clause (c) of the definition of “enabler facility” applies:

- (a) the capacity of the associated renewable resource cluster is at least 100 MW; and
- (b) if the proposed enabler facility is a line connection facility, either:
 - i. the proposed line connection facility is at least 10 km in length; or

- ii. the OPA has satisfied the Board that the line connection facility should qualify as an enabler facility because such treatment would be superior, for technical or cost effectiveness reasons, to the generation facilities in the associated renewable resource cluster connecting directly to the transmitter's existing transmission facilities individually or on a coordinated basis.

3A.2 Nothing in section 3A.1 shall prevent the Board from determining, in a proceeding to consider an application made under section 92 of the Act or a process commenced to address the issue of the continued qualification of a connection facility as an enabler facility, that a connection facility should maintain its qualification as an enabler facility notwithstanding that the enabler facility no longer satisfies the screening criteria set out in section 3A.1, if the Board is satisfied that the deficiency is not material in the circumstances.

3B. RELIABILITY AND INTEGRITY OF TRANSMISSION SYSTEM

3B.1 A transmitter shall, in accordance with the Act, its licence and this Code, maintain the reliability and integrity of its transmission system and reinforce or expand its transmission system as required to meet load growth.

3B.2 Cyber Security

3B.2.1 Definitions

"Cyber Security" means a body of technologies, processes, and practices designed to protect networks, computers, programs, data and personal information from attack, damage or unauthorized access. Cyber security includes electronic security and physical security issues as they relate to cyber security protection.

"Cyber Security Framework" means the Ontario Cyber Security Framework that was issued December 20, 2017, or the current version of the document.

3B.2.2 Reporting

3B.2.2.1

A transmitter shall report to the Board on the status of cyber security readiness referencing the Cyber Security Framework at such times and in such a manner as may be directed by the Board.

3B.2.2.2

The Chief Executive Officer of the transmitter shall certify the transmitter's reported cyber security readiness in such form as may be required by the Board.

3B.2.3 Continuing Obligations Regarding Transmission System and Privacy

Nothing in this section 3B.2 shall limit any obligations of a transmitter to maintain the reliability and integrity of its transmission system, and to protect personal information.

3C. REGIONAL PLANNING

3C.1 DEFINITIONS AND LEAD RESPONSIBILITY WHERE MORE THAN ONE TRANSMITTER IN A REGION

3C.1.1 For the purposes of this section 3C:

"Integrated Regional Resource Plan" means a document prepared by the OPA that identifies the appropriate mix of investments in one or more of conservation and demand management, generation, transmission facilities or distribution facilities in order to address the electricity needs of a region in the near- (up to 5 years), mid- (5 to 10 years), and long-term (more than 10 and up to 20 years);

"integrated regional resource planning process" means a planning process led by the OPA for the purpose of determining the appropriate mix of investments in one or more of conservation and demand management, generation, transmission facilities or distribution facilities in order to address the electricity needs of a region in the near- (up to 5 years), mid- (5 to 10 years), and long-term (more than 10 and up to 20 years);

"needs assessment" means a process led by a transmitter to determine if regional planning is required for a region;

"region", in respect of a transmitter, means an area within which the transmitter's transmission system is located, in whole or in part, and that has been designated as such by the transmitter, in consultation with the OPA, under section 3C.2.2(a) for regional planning purposes;

"Regional Infrastructure Plan" means a document prepared by the transmitter leading a regional infrastructure planning process that identifies investments in transmission

facilities, distribution facilities or both that should be developed and implemented on a coordinated basis to meet the electricity infrastructure needs within a region;

“regional infrastructure planning process” means a planning process led by a transmitter in accordance with this section 3C for the purpose of determining the investments in transmission facilities, distribution facilities or both that should be developed and implemented on a coordinated basis to meet the electricity infrastructure needs within a region;

“regional planning” means a planning process involving licensed transmitter(s), licensed distributor(s), and the OPA for the purpose of determining whether a Regional Infrastructure Plan and/or an Integrated Regional Resource Plan is required for a region and, where required, developing or updating a Regional Infrastructure Plan and/or an Integrated Regional Resource Plan; and

“scoping assessment” means a process led by the OPA to determine the form of regional planning process (regional infrastructure planning process or integrated regional resource planning process) that is required for a region.

3C.1.2 For the purposes of this section 3C, where the transmission system of more than one licensed transmitter is connected to customers in a region, the applicable transmitters shall determine which among them will be responsible for leading the regional infrastructure planning processes for the region at any given time. The applicable transmitters shall make that determination within 30 days of August 26, 2013, and may agree to change that determination from time to time thereafter. The transmitter that has been so designated at any given time shall be responsible for complying with the obligations set out in this section 3C. The other transmitter(s) shall participate in any regional infrastructure planning process or integrated regional resource planning process for the region as reasonably required by the lead transmitter or the OPA, as applicable, but shall not otherwise be required to comply with the obligations set out in this section 3C.

3C.2 OBLIGATION TO LEAD REGIONAL INFRASTRUCTURE PLANNING PROCESS

3C.2.1 A transmitter shall, in consultation with the OPA and with all applicable licensed distributors and licensed transmitters in a region, lead a regional infrastructure planning process for each region and participate in any integrated regional resource planning process for the region.

3C.2.2 For the purposes of section 3C.2.1, a transmitter shall:

- (a) review the boundaries of the regions, in consultation with the OPA, no less than once every five years to determine whether they need to be modified;
- (b) from time to time as required, and on a timely basis, request information from all licensed distributors and licensed transmitters in a region and from the OPA that the transmitter considers is reasonably required for the purpose of undertaking a needs assessment in relation to the region;
- (c) for each region, conduct a needs assessment at least every five years, and more frequently if required by reason of forecasted load or demand growth within a distributor's licensed service area, request(s) for connection received by the transmitter or other events that the transmitter believes may trigger the need for investment in transmission facilities, distribution facilities or both in a region. The needs assessment for a region shall be completed within 60 days of receipt of the information referred to in section 3C.2.2(b);
- (d) within 10 days of completion of a needs assessment for a region, provide a report to the OPA, the IESO, and all licensed distributors and licensed transmitters within the region that reflects the results of the needs assessment, including the identity of the licensed distributors that will and will not need to be involved in further regional planning activities for the region, and post that report on its website;
- (e) where a needs assessment for a region indicates that a scoping assessment is required, participate in the scoping assessment as may be reasonably required by the OPA;
- (f) where a scoping assessment identifies that a regional infrastructure planning process is required for a region, complete or update a Regional Infrastructure Plan for the region within six months of the date of receipt of the scoping assessment from the OPA, and post the Regional Infrastructure Plan on its website upon its completion;
- (g) where a scoping assessment identifies that an integrated regional resource planning process is required for a region, (i) participate in the integrated regional resource planning process as may be reasonably

required by the OPA, and (ii) subject to section 3C.2.3, provide the OPA with such information as the OPA may from time to time reasonably require for the purposes of the integrated regional resource planning process within 30 days of receipt of a request by the OPA for the information; and

- (h) within 45 days of receipt of a request to do so, provide a letter to a licensed distributor or a licensed transmitter confirming the status of regional planning for a region, including any Regional Infrastructure Plan that is being developed for the region that includes the distributor's licensed service area or within which the requesting transmitter's transmission system is located, suitable for the purpose of supporting an application proposed to be filed with the Board by the distributor or requesting transmitter.

3C.2.3 Where a transmitter believes that it cannot meet the 30-day timeline referred to in part (ii) of section 3C.2.2(g), the transmitter and the OPA may agree to a longer timeline. In such a case, the transmitter shall so notify the Board in writing. The notice shall indicate the region in question, the reasons for being unable to meet the 30-day timeline and the extended timeline that has been agreed to between the transmitter and the OPA.

3C.3 MONITORING AND REPORTING

3C.3.1 Subject to section 3C.3.2, a transmitter shall, in consultation with the OPA and with all applicable licensed distributors and licensed transmitters in a region for which a Regional Infrastructure Plan has been completed, undertake a review every 12 months following the completion of the Regional Infrastructure Plan for the purpose of determining:

- (a) whether the investments in transmission facilities, distribution facilities or both, as applicable, identified in the Regional Infrastructure Plan are being implemented in accordance with the schedule set out in the Plan; and
- (b) whether the Regional Infrastructure Plan needs to be updated in advance of the next scheduled needs assessment for the region.

3C.3.2 Where a Regional Infrastructure Plan for a region includes only investments in distribution facilities, a transmitter may make arrangements for a licensed distributor in the region to conduct the review referred to in section 3C.3.1(a) rather than conducting the review itself. In such a case, the transmitter shall request a report from the distributor setting out the status of the investments set out in the Regional Infrastructure Plan at least 60 days in advance of the filing of the annual status report referred to in section 3C.3.3.

3C.3.3 A transmitter shall submit an annual report to the Board, on November 1st of each year, that identifies the status of regional planning for all regions, and shall post the report on its website. The report shall include the status of investments in conservation and demand management, generation or both for each region for which an Integrated Regional Resource Plan has been completed, provided that this information has been provided to the transmitter by the OPA no later than October 1st of the year.

3C.4 TRANSITION

3C.4.1 A transmitter shall, within 10 days of August 26, 2013, request from each licensed distributor whose distribution system is connected to its transmission system a letter identifying whether the distributor foresees a potential need for additional transmission connection capacity to support the needs of the distributor's distribution system and of the distribution system of any of that distributor's embedded licensed distributors over the next five years.

3C.4.2 A transmitter shall, within 90 days of August 26, 2013, complete a review of all regions to prioritize them based on the anticipated timing of the need for investment in transmission facilities, distribution facilities or both. Every 12 months following August 26, 2013, the transmitter shall review the prioritization of regions and revise it as required to reflect emerging needs in the regions. The transmitter shall maintain a priority list, post it on its website and update it as required to reflect any changes in prioritization.

3C.4.3 A transmitter shall, within 10 days of completing a review referred to in section 3C.4.2:

- (a) notify the licensed distributors and licensed transmitters within a region regarding whether they need to be involved in regional planning for the region; and
- (b) provide a report to the OPA identifying whether regional planning is required for each region and, where it is required, the identity of the licensed distributors and licensed transmitters in the region that need to be involved in regional planning for the region.

3C.4.4 A transmitter shall undertake a needs assessments for each region in accordance with the priority list referred to in section 3C.4.2. Within four years of August 26, 2013, the transmitter shall complete a needs assessment for all regions, and complete a Regional Infrastructure Plan for each region where one is required.

4. STANDARDS OF BUSINESS PRACTICE AND CONDUCT

4.1 GENERAL REQUIREMENTS

- 4.1.1 Subject to section 4.1.2, a transmitter shall connect a customer's facilities and shall offer and provide transmission services to a customer subject to that customer entering into or having a connection agreement with the transmitter. Such connection agreement shall be in the form set out in the applicable version of the connection agreement set out in Appendix 1. Where the customer is an unlicensed transmitter, the version of the connection agreement set out in Appendix 1 to be used shall be determined based on the nature of the facility that is connected to the unlicensed transmitter's transmission system. Where both a generation facility and a load facility are connected to the unlicensed transmitter's transmission system, this may require two connection agreements.
- 4.1.2 A transmitter may not enter into a connection agreement on terms and conditions other than those set forth in the applicable version of the connection agreement set out in Appendix 1 or amend the terms and conditions of a connection agreement relative to the terms and conditions set forth in the applicable version of the connection agreement set out in Appendix 1 except as expressly contemplated in the applicable version of the connection agreement set out in Appendix 1 or with the prior approval of the Board.
- 4.1.3 Where a transmitter does not have a connection agreement with a customer whose facilities were connected to the transmitter's transmission system prior to the Code revision date, the transmitter shall be bound by the applicable version of the connection agreement set out in Appendix 1 in relation to that customer and shall be permitted to consider that customer's continued acceptance of transmission service as acceptance by that customer of all of the terms and conditions of the connection agreement in the form set out in the applicable version of the connection agreement set out in Appendix 1.
- 4.1.4 A transmitter shall ensure that all connections to its transmission system are made by it with due regard for the safety of the transmitter's employees and the public.

- 4.1.5 A transmitter shall provide customers and any neighbouring Ontario transmitter with all necessary information that is in the possession of or reasonably available to the transmitter to enable the transmitter to comply with its obligations under this Code, including the information specified in Appendix 3.
- 4.1.6 Except as may be required by section 4.1.1 in relation to a customer that is an unlicensed transmitter, a transmitter may not require more than one connection agreement from a customer whose facilities will be or are connected either at a single site or at multiple sites or service territories that are geographically contiguous. A transmitter shall require a separate connection agreement for each facility that a customer may have at geographically noncontiguous sites or service territories.

4.2 TRANSMISSION SERVICE CHARGES

- 4.2.1 A transmitter shall maintain and make available to all customers a list of its transmission services and the rates or charges approved by the Board for those transmission services.
- 4.2.2 No transmitter shall charge a customer for any transmission service unless the charge has been approved by the Board.
- 4.2.3 A transmitter shall not charge a customer for any transmission services in relation to any reduction in that customer's load that the customer has demonstrated to the reasonable satisfaction of the transmitter (such as by means of an energy study or audit) has resulted from embedded renewable generation (determined in accordance with section 11.1), energy conservation, energy efficiency or load management activities, except in accordance with the transmitter's Rate Order.
- 4.2.4 A transmitter shall not impose or enforce a minimum payment obligation on any customer, except in accordance with this Code or a Rate Order.

4.3 FACILITIES STANDARDS

- 4.3.1 A transmitter shall ensure that its transmission facilities:
- (a) meet all applicable requirements of the Ontario Electrical Safety Authority;
 - (b) conform to applicable industry standards, including those of the Canadian Standards Association, the Institute of Electrical and Electronic Engineers, the American National Standards Institute, and the International Electrotechnical Commission;
 - (c) are designed and constructed in accordance with the instruments and standards referred to in section 5.1.2; and
 - (d) comply with the basic general performance standards and technical requirements for facilities that are set out in this Code, including Appendix 2.
- 4.3.2 The basic general performance standards and minimum technical requirements for facilities, except facilities deemed compliant under section 4.6.1, are set out in this Code, including Appendix 2. A transmitter shall provide the appropriate technical parameters to assist a customer in designing its facilities so that they are compliant with those basic general performance standards.
- 4.3.3 A transmitter may participate in the commissioning, inspecting, and testing of customer-owned connection facilities to ensure that facilities connected to its transmission system will not materially reduce or adversely affect the reliability of its transmission system. The transmitter shall recover its reasonable costs of participating in the commissioning, inspection or testing of the customer-owned connection facilities from the customer.
- 4.3.4 Where section 4.3.3 applies, the commissioning, inspection or testing of the customer's facilities shall be conducted at a time that is mutually agreed by the customer and the transmitter. If the commissioning, inspection or testing is required to be rescheduled at the request of the transmitter or by reason of the transmitter's failure to attend, the transmitter shall, if so requested by the customer, pay all reasonable costs incurred by the customer in respect of the rescheduling of the commissioning, inspection or testing activity. If the commissioning, inspection or testing is required to be rescheduled at the request of the customer or by reason of the customer's failure to attend, the transmitter may recover from the customer the reasonable costs incurred by

the transmitter in respect of the rescheduling of the commissioning, inspection or testing activity.

4.4 OPERATIONAL STANDARDS AND REPORTING PROTOCOL

- 4.4.1 A transmitter shall take reasonable steps to ensure that all facilities connected to its transmission system are operated and maintained in accordance with the requirements of this Code and all connection agreements.
- 4.4.2 Upon request by a customer or a neighbouring Ontario transmitter, a transmitter shall provide the fault levels at all relevant connection points.
- 4.4.3 A transmitter shall promptly report to a customer or a neighbouring Ontario transmitter any changes in the transmitter's transmission facilities, or in the facilities of another customer or neighbouring Ontario transmitter if known, that could materially affect the transmission services provided to that customer or neighbouring Ontario transmitter.

4.5 PERFORMANCE STANDARDS

- 4.5.1 A transmitter shall develop performance standards that apply at the customer delivery point level and that:
 - (a) reflect typical transmission system configurations that take into account the historical development of the transmitter's transmission system at the customer delivery point level;
 - (b) reflect historical performance at the customer delivery point level;
 - (c) are, where applicable, consistent with the comparable performance standards applicable to all delivery points throughout the transmitter's transmission system;
 - (d) establish acceptable bands of performance at the customer delivery point level for transmission system configurations, geographic area, load, and capacity levels;
 - (e) establish appropriate triggering events to be used to initiate technical and economic evaluations by the transmitter and its customers regarding

performance standards at the customer delivery point level, as well as the circumstances in which any such triggering event will not require the initiation of a technical or economic evaluation;

- (f) establish the steps to be taken based on the results of any evaluation that has been so triggered, as well as the circumstances in which such steps need not be taken; and
- (g) establish any circumstances in which the performance standards will not apply.

4.5.2 To the extent that it has not already done so prior to the Code revision date, a transmitter shall file the performance standards referred to in section 4.5.1 for the Board's approval within one year of the Code revision date. A transmitter shall also file any material amendments to those performance standards for the Board's approval. The transmitter may not give effect to such performance standards or any material amendments thereto until the performance standards or amendments have been approved by the Board or amended by the Board under section 4.5.3.

4.5.3 The Board may, on application or on its own motion, amend a transmitter's performance standards and any amendments thereto that have previously been approved by the Board under section 4.5.2 or 4.5.4 or amended by the Board under this section 4.5.3.

4.5.4 Where, prior to the Code revision date, a transmitter had filed its performance standards with the Board and such performance standards do not contain all of the material required by section 4.5.1, the transmitter shall file the missing material within one year of the Code revision date. The Board may make a decision regarding the incomplete performance standards pending the filing of the missing material.

4.5.5 A transmitter shall publish on its website its Board-approved performance standards referred to in section 4.5.1, and shall make those performance standards available upon request.

4.5.6 A transmitter's performance standards that were approved by the Board, in whole or in part, prior to the Code revision date shall be deemed to have been so approved by the Board under this section 4.5.

4.6 COMPLIANCE OF FACILITIES WITH STANDARDS

- 4.6.1 All facilities that came into service, were procured or were ordered prior to May 1, 2002 are deemed to be in compliance with the performance standards and technical requirements contained in this Code, including Appendix 2.
- 4.6.2 A transmitter may require that customer facilities that have been deemed compliant under section 4.6.1 be brought into actual compliance with the performance standards or technical requirements set out in this Code, including Appendix 2, within a specified time period where the transmitter has identified that:
- (a) there is a material deterioration in the reliability of its transmission system resulting from the performance of the deemed compliant facilities;
 - (b) there are material negative impacts on another customer's or on a neighbouring Ontario transmitter's power quality resulting from the performance of the deemed compliant facilities; or
 - (c) there is a material increase in capacity or load at the site where the deemed compliant facilities are located.
- 4.6.3 A transmitter may not act in accordance with section 4.6.2 until the transmitter has developed rules and procedures for requiring customer facilities to be brought into actual compliance and those rules and procedures have been approved by the Board. A transmitter may not give effect to a material amendment to such rules and procedures until the amendment has been approved by the Board or made by the Board under section 4.6.4.
- 4.6.4 The Board may, on application or on its own motion, amend a transmitter's rules and procedures and any amendments thereto that have been previously approved by the Board under section 4.6.3 or amended by the Board under this section 4.6.4.
- 4.6.5 If a transmitter's transmission facilities that have been deemed compliant under section 4.6.1 are considered by the transmitter or a customer to be

causing any of the effects referred to in sections 4.6.2(a) to 4.6.2(c), the transmitter shall bring those transmission facilities into actual compliance.

- 4.6.6 A transmitter shall publish on its website its Board-approved rules and procedures referred to in section 4.6.3, and shall make those rules and procedures available upon request.
- 4.6.7 A transmitter's rules and procedures referred to in section 4.6.3 that were approved by the Board, in whole or in part, prior to the Code revision date shall be deemed to have been so approved by the Board under this section 4.6.

4.7 CONFIDENTIALITY

- 4.7.1 Subject to section 4.7.2, a transmitter shall not, in performing its obligations or exercising its rights under this Code or under any of the transmitter's procedures or performance standards referred to in this Code, disclose confidential information relating to a customer or a neighbouring Ontario transmitter to another person without the consent of the customer or neighbouring Ontario transmitter to whom the confidential information relates. Where such consent cannot be obtained, the transmitter may request guidance from the Board.
- 4.7.2 Nothing in section 4.7.1 shall prevent the disclosure of confidential information by a transmitter:
- (a) where required under this Code, the Market Rules or the transmitter's licence;
 - (b) where required by law or regulatory requirements;
 - (c) where required by order of a government, government agency or regulatory body or agency having jurisdiction;
 - (d) if required in connection with legal proceedings, arbitration or any expert determination relating to the subject matter of this Code, or for the purpose of advising the transmitter in relation thereto;
 - (e) as may be required to enable the transmitter to fulfill its obligations to any reliability organization;

- (f) where permitted by the applicable connection agreement or the applicable agreement referred to in section 6.8.1; or
- (g) as may be required in an emergency or to prevent or minimize the effect of an emergency.

5. REQUIREMENTS FOR OPERATIONS AND MAINTENANCE

5.1 DAY-TO-DAY OPERATIONS

- 5.1.1 A transmitter shall ensure that the operation and maintenance of its transmission facilities are performed only by persons qualified to do so.
- 5.1.2 A transmitter shall operate and maintain its transmission facilities in compliance with this Code, its licence, its operating agreement with the IESO, the Market Rules, all connection agreements, good utility practice, the standards of all applicable reliability organizations and any applicable law.

5.2 FORCED OUTAGES

- 5.2.1 When a forced outage of a transmitter's transmission facilities adversely affects any customer facilities, the transmitter shall follow the procedures set out in the relevant sections of the applicable connection agreement.
- 5.2.2 When a forced outage of a transmitter's transmission facilities adversely affects the facilities of a neighbouring Ontario transmitter, the transmitter shall follow the procedures set out in the relevant sections of the applicable agreement referred to in section 6.8.1.

5.3 SCHEDULING OF PLANNED WORK

- 5.3.1 A transmitter shall follow the procedures for the scheduling of planned work which are set out in its connection agreements and in any agreements referred to in section 6.8.1.
- 5.3.2 A transmitter shall coordinate outages arising from planned work scheduled by a customer or a neighbouring Ontario transmitter that directly affect the transmitter's transmission facilities.
- 5.3.3 A transmitter shall, to the best of its ability, obtain from its customers and from any neighbouring Ontario transmitters their anticipated planned outages for the upcoming year by October 1st of each year.

5.4 EMERGENCY OPERATIONS

5.4.1 During an emergency or in order to prevent or minimize the effects of an emergency, a transmitter may take whatever immediate action it deems necessary to ensure public safety or to safeguard life, property or the environment without first notifying any other person. Without limiting the generality of the foregoing, during an emergency or in order to prevent or minimize the effects of an emergency a transmitter may:

- (a) order the switching of equipment;
- (b) disconnect the facilities of a customer or of a neighbouring Ontario transmitter; or
- (c) require that a customer or a neighbouring Ontario transmitter disconnect its facilities,

in accordance with the applicable connection agreement or agreement referred to in section 6.8.1, as the case may be.

5.4.2 A transmitter that takes action under section 5.4.1 shall promptly report the action taken and the reason for it to all affected customers and neighbouring Ontario transmitters.

5.4.3 A transmitter shall implement load shedding as directed by the IESO and as specified in its connection agreements.

5.4.4 During an emergency or in order to prevent or minimize the effects of an emergency, a transmitter may interrupt supply to a customer or a neighbouring Ontario transmitter to protect the stability, reliability, or integrity of the transmitter's transmission facilities, or to maintain the availability of its transmission facilities. The transmitter shall advise all affected customers and neighbouring Ontario transmitters as soon as possible of the transmitter's transmission system's emergency status and of when to expect the resumption of normal operations and the reconnection of their facilities to the transmission system.

5.4.5 When a transmitter's transmission facilities return to normal operation following an emergency, the transmitter shall notify each affected customer and neighbouring Ontario transmitter as soon as possible that it may reconnect its facilities.

6. CUSTOMER CONNECTIONS

6.1 GENERAL REQUIREMENTS

- 6.1.1 A transmitter shall design and construct its new or modified connection facilities on a timely basis and in accordance with the connection procedures referred to in section 6.1.3 and all applicable standards and instruments referred to in section 5.1.2.
- 6.1.2 A transmitter shall ensure that new or modified connections to its transmission system are made in accordance with the cost responsibility principles set out in this Code and that they:
- (a) do not materially reduce the reliability or performance of its transmission system; and
 - (b) are constructed with such mitigation measures as may be required so that no new available fault current level referred to in section 6.4.4 exceeds the maximum allowable fault levels set out in Appendix 2 if this would have an adverse effect on any person.

Where the new available fault current level would exceed the maximum allowable fault level set out in Appendix 2 and would have an adverse effect on a person the transmitter may, as an alternative to satisfying the requirements of section 6.1.2(b), make suitable financial arrangements agreeable to the connecting customer and all affected persons to mitigate the economic or financial impact of allowing the new available fault current level to exceed the maximum allowable fault level set out in Appendix 2. Such arrangements shall be consistent with the cost responsibility principles set out in the Code.

- 6.1.3 A transmitter shall publish on its website its Board-approved connection procedures for processing requests to connect to its transmission system or to modify existing connections, and shall make those connection procedures available upon request. A transmitter's connection procedures shall be consistent with this Code and shall be consistent with and complementary to the Market Rules and the IESO's market procedures as they relate to connection.
- 6.1.4 A transmitter's connection procedures referred to in section 6.1.3 shall

include the following:

- (a) a procedure for determining the total normal supply capacity of a connection facility as required by section 6.2.7;
- (b) an available capacity procedure that complies with section 6.2.11;
- (c) a security deposit procedure that complies with section 6.3.11;
- (d) a customer impact assessment procedure that complies with section 6.4.1;
- (e) an economic evaluation procedure that complies with section 6.5.2;
- (f) a contestability procedure that complies with section 6.6.2;
- (g) a reconnection procedure that complies with section 6.10.3;
- (h) a dispute resolution procedure that complies with section 12.1.1;
- (i) an obligation on the transmitter to provide a customer with the most recent version of the Regional Infrastructure Plan or Integrated Regional Resource Plan referred to in section 3C, if an, that covers the applicable portion of its transmission system;
- (j) a schedule of all charges and fees that may be charged by the transmitter and that are not covered by the transmitter's Rate Order; and
- (k) reasonable timelines within which activities covered by the procedures referred to in paragraphs (a) to (g) and (i) must be completed by the transmitter or the customer, as applicable, including typical construction times for facilities.

6.1.5 Intentionally left blank.

6.1.6 The Board may, on application or on its own motion, amend a transmitter's connection procedures and any amendments thereto that have been previously approved or amended by the Board under this section 6.1.6.

6.1.7 Intentionally left blank.

6.1.8 Until such time as a transmitter's connection procedures have been approved by the Board, the transmitter shall process requests for connection and deal with the other matters listed in section 6.1.4 in accordance with all applicable provisions of this Code and otherwise in a manner that is

reasonable and consistent with this Code, the Act, the Electricity Act and its licence. A dispute between a transmitter and a customer that arises in relation to any matter listed in section 6.1.4 prior to the approval by the Board of the transmitter's connection procedures may be submitted to the Board for determination where either the transmitter or the customer allege that the other is:

- (a) seeking to impose a term or condition that is inconsistent with or contrary to the Act, the Electricity Act, a party's licence or this Code; or
- (b) refusing to include a term or condition that is required to give effect to this Code.

6.1.9 A transmitter's connection procedures shall not unjustly discriminate among customers or unduly restrict the ability of any person to connect its facilities to the transmitter's transmission system.

6.1.10 A transmitter shall not connect a customer's facilities or any new, modified or replacement customer facilities unless any required connection authorization, certificate of inspection or other applicable approval or authorization has been issued or given by the Ontario Electrical Safety Authority in relation to such facilities. A transmitter may require, as a condition of connecting a customer's facilities or any new, modified or replacement customer facilities, that the customer provide it with the same technical information provided to the IESO during any connection assessment and facility registration processes associated with the customer's facilities or any new, modified or replacement customer facilities. The transmitter shall require that such information be provided in the form outlined in the applicable sections of the IESO's public website.

6.1.11 A transmitter may require, as a condition of connecting a customer's facilities or any new, modified or replacement customer facilities, that the customer provide it with test certificates certifying that the customer's facilities have passed all relevant tests and comply with all applicable instruments and standards referred to in section 5.1.2, comply with all applicable instruments and standards referred to in section 5.1.2, including any certificates of inspection or other applicable approvals or authorizations that may be required by the Ontario Electrical Safety Authority.

- 6.1.12 A transmitter shall provide to a customer such technical parameters as may be required to assist the customer in ensuring that the design of the customer's facilities or of any new, modified or replacement customer facilities is consistent with the requirements applicable to the transmitter's transmission system.
- 6.1.13 A transmitter shall cooperate with a customer to ensure that modeling data that may be required for the planning, design and operation of connections are complete and accurate. The transmitter shall conduct, or may require that the customer conduct, such tests as may be required where the transmitter believes on reasonable grounds that the accuracy of such data is in question. Where the tests are conducted by the transmitter:
- (a) the transmitter may require that the customer reimburse the transmitter for the costs and expenses reasonably incurred by the transmitter in conducting the tests;
 - (b) the tests shall be conducted at a time that is mutually agreed by the customer and the transmitter; and
 - (c) the transmitter shall promptly report the results of such tests to the customer.

If a test is required to be rescheduled at the request of the transmitter or by reason of the transmitter's failure to attend, the transmitter shall, if so requested by the customer, pay all reasonable costs incurred by the customer in respect of the rescheduling of the test. If a test is required to be rescheduled at the request of the customer or by reason of the customer's failure to attend, the transmitter may recover from the customer all reasonable costs incurred by the transmitter in respect of the rescheduling of the test.

6.2 AVAILABLE CAPACITY

6.2.1 A transmitter shall not assign available capacity on network facilities. A transmitter shall not assign available capacity on its connection facilities for back-up purposes.

6.2.2 A load customer's assigned capacity in relation to a connection facility shall be equal to the aggregate of:

- (a) the customer's highest rolling three-month average peak load under normal operating conditions:
 - i. in the most recent five years, where the determination of the customer's assigned capacity is made after May 1, 2007, or
 - ii. since May 1, 2002, where the determination of the customer's assigned capacity is made on or before May 1, 2007; and
- (b) any available capacity that has been assigned to the customer and that has not yet been taken up by the customer nor cancelled by the transmitter under section 6.2.19.

If a load customer's facility has been connected to the connection facility for a period of less than five years, for purposes of determining the customer's assigned capacity the transmitter shall use the customer's highest rolling three-month average peak load in the year or years during which the customer's facility has been connected to the connection facility. Where a transmitter reasonably believes that a customer is manipulating its load for the purpose of the determination of its assigned capacity, the transmitter may request that the Board review and re-determine that assigned capacity.

6.2.3 Where an economic evaluation, including an economic evaluation referred to in section 6.3.9 or 6.3.17A, was conducted by a transmitter for a load customer in relation to a connection facility on the basis of a load forecast, that customer's contracted capacity shall, during the economic evaluation period to which the economic evaluation relates, be equal to the load identified in that load forecast or in any subsequent forecast used for purposes of giving effect to the true-up provisions of section 6.5.

6.2.4 A load customer with contracted capacity on a connection facility shall, in any year, be entitled to capacity in an amount that is equal to:

- (a) the amount of capacity for that year as specified in the applicable load forecast referred to in section 6.2.3; or
- (b) the customer's assigned capacity for that year,

whichever is greater.

6.2.5 Notwithstanding any assignments of available capacity that a transmitter may make under this section 6.2, the transmitter shall ensure that there is sufficient available capacity on the transmitter's connection facility to satisfy:

- (a) the capacity entitlement of each load customer on that connection facility, determined in accordance with section 6.2.4; and
- (b) the assigned capacity and the contracted capacity of all load customers in relation to that connection facility at the relevant time.

The transmitter shall conduct an expansion study where the transmitter considers it necessary to ensure that it can meet this obligation.

6.2.6 A transmitter shall from time to time as required determine the total assigned capacity on a connection facility. For that purpose, the total assigned capacity shall be the aggregate of the assigned capacity of each load customer whose facilities are then served by the connection facility. In making this determination, the transmitter shall take into account the normal size and shape of the load of each load customer served by the connection facility, excluding anomalous situations such as reconfigurations that may be required by the IESO, temporary load transfers, or emergencies.

6.2.7 A transmitter shall from time to time as required determine the available capacity on a connection facility. For that purpose, the available capacity shall be determined by subtracting the total assigned capacity on that connection facility, determined in accordance with section 6.2.6, from the total normal supply capacity for that connection facility. The transmitter shall establish in its connection procedures referred to in section 6.1.4 and implement a procedure to determine the total normal supply capacity of a transformation connection facility and a line connection facility.

- 6.2.8 Where a load customer requests an assignment of capacity on a connection facility, the transmitter shall determine the available capacity of that connection facility.
- 6.2.9 A transmitter shall from time to time as required monitor the available capacity on its connection facilities.
- 6.2.10 Subject to section 6.2.12(e), a transmitter shall assign available capacity on a connection facility to load customers on a first-come first-served basis. A transmitter shall not assign capacity to a load customer unless the customer has demonstrated its need for available capacity in accordance with the requirements of the transmitter's available capacity procedure referred to in section 6.2.12(d). This obligation shall apply whether or not implementation of the available capacity procedure is required by section 6.2.11.
- 6.2.11 A transmitter shall establish an available capacity procedure in its connection procedures referred to in section 6.1.4. The transmitter shall implement the available capacity procedure when:
- (a) the available capacity on a connection facility is reduced to 25% or less of the total normal supply capacity of that connection facility; or
 - (b) a load customer requests supply capacity on a connection facility that would reduce the available capacity on that connection facility to 25% or less of the total normal supply capacity of that connection facility.
- 6.2.12 The available capacity procedure referred to in section 6.2.11 shall include provisions that:
- (a) specify how load customers will be notified that implementation of the available capacity procedure has been triggered as required by section 6.2.11;
 - (b) set out how load customers may apply for available capacity in relation to the applicable connection facility;
 - (c) establish a reasonable amount of time for a load customer to make such an application;
 - (d) set out how a load customer demonstrates its need for available capacity on the applicable connection facility;

- (e) where there is more than one application for available capacity on the applicable connection facility based on demonstrated need, establish that available capacity will be assigned to the relevant load customers in proportion to their respective needs; and
- (f) establish the circumstances under which an expansion study will be carried out.

6.2.13 Where a transmitter assigns capacity on a connection facility to itself (in its capacity as a customer) or to a load customer that is an affiliate of the transmitter, the transmitter shall give notice of such assignment to all other customers served by that connection facility regardless of whether such assignment triggers implementation of the available capacity procedure under section 6.2.11.

6.2.14 When a transmitter proposes to carry out an expansion study under section 6.2.5 or 6.2.12(f) in relation to the provision of new supply capacity by means of an increase in the capacity of an existing connection facility or the construction of a new connection facility, the transmitter shall notify all load customers served or that the transmitter then knows are expected to be served by the existing or the proposed new connection facility. The transmitter shall also post on its website a notice of its proposal to carry out such an expansion study and of the right of load customers served by existing adjacent connection facilities to apply to reconfigure their respective load as described in section 6.2.15.

6.2.15 Where a new connection facility is proposed under section 6.2.14, the transmitter shall use best efforts to notify all load customers served by existing connection facilities adjacent to the proposed new connection facility. Such notice shall advise each load customer that it may apply to the transmitter to reconfigure load representing its assigned capacity or its contracted capacity to the proposed new connection facility. Where a load customer makes such an application, the transmitter shall negotiate in good faith with the customer to determine the terms and conditions that will govern the reconfiguration. Where the transmitter receives applications from load customers in circumstances where the applications cannot all be accommodated by the transmitter, the transmitter shall nonetheless negotiate in good faith with all such customers to determine the terms and conditions that will govern the reconfiguration, and shall then reconfigure the load of

each load customer with whom it has successfully negotiated such terms and conditions in proportion to its assigned capacity or contracted capacity.

- 6.2.16 Upon completion of an expansion study, the transmitter shall advise all affected load customers of the available capacity on all relevant existing and new connection facilities before and after the expansion.
- 6.2.17 Where available capacity is assigned to a load customer in relation to a connection facility and the customer has a connection agreement, the contracted capacity and load shape shall be specified in the connection agreement.
- 6.2.18 Subject to section 6.2.19, available capacity that has been assigned to a load customer in relation to a connection facility may not, without the consent of the customer, be reassigned by a transmitter nor be reassigned by the customer except in connection with a change in ownership of the facility to which the assigned capacity relates. A transmitter shall, upon request, reassign assigned capacity as required to reflect such change in ownership.
- 6.2.19 Subject to section 6.2.20, where available capacity on a connection facility has been assigned to a load customer by a transmitter, and that capacity has not been taken up by the customer within one year of the assignment (except where that capacity is included in a load forecast referred to in section 6.2.3), the transmitter shall:
- (a) cancel the assignment;
 - (b) treat such capacity as available capacity; and
 - (c) notify all other load customers whose facilities are served by that connection facility of the cancellation of the assignment.

The one-year period continues to run regardless of any change in the ownership of the facility to which the assigned capacity relates or of any reassignment of the assigned capacity as a result of that change in ownership.

- 6.2.20 A load customer may request that the transmitter extend the one-year period referred to in section 6.2.19 where circumstances warrant, such as where the customer is constructing new facilities that require more than one year to come into service. A transmitter shall not unreasonably deny such a request.

Where the transmitter denies such a request, the customer may apply to the Board for an order requiring the transmitter to extend the one-year period.

- 6.2.21 Where a transmitter extends the one-year period referred to in section 6.2.19 in relation to itself (in its capacity as a customer) or a load customer that is an affiliate of the transmitter, the transmitter shall give notice of such extension to all other load customers served by the applicable connection facility.
- 6.2.22 Upon request, a transmitter shall assign available capacity on a transmitter-owned connection facility to serve an existing load customer's new load unless the transmitter can demonstrate that the available capacity will not meet the customer's needs.
- 6.2.23 When a load customer provides its own connection facility to serve new load, the transmitter shall not assign capacity on the relevant transmitter-owned connection facility to that customer in relation to that new load.
- 6.2.24 Note: Section 6.2.24 revoked by amendment, effective August 26, 2013.
- 6.2.25 Note: Section 6.2.25 revoked by amendment, effective August 26, 2013.
- 6.2.26 Subject to section 6.2.27, a transmitter shall advise a load customer of the available capacity on a specific connection facility, upon request.
- 6.2.27 Without limiting the generality of section 4.7.1, in providing information with respect to available capacity to any person, a transmitter shall protect confidential information about any customer. Subject to section 6.2.16, before disclosing the available capacity on a connection facility that serves only one customer, the transmitter shall obtain the consent of that customer. Where such consent cannot be obtained, the transmitter may request guidance from the Board.

6.3 COST RESPONSIBILITY FOR NEW AND MODIFIED CONNECTIONS

- 6.3.1 Where a load customer elects to be served by transmitter-owned connection facilities, a transmitter shall require a capital contribution from the load customer to cover the cost of a connection facility required to meet the load customer's needs. A capital contribution may only be required to the extent that the cost of the connection facility is not recoverable in connection rate revenues. To that end, the transmitter shall include in the economic evaluation the relevant annual connection rate revenues over the applicable economic evaluation period that are derived from that part of the customer's new load that exceeds the total normal supply capacity of any connection facility already serving the customer and that will be served by the new connection facility. The transmitter shall calculate any capital contribution to be made by the load customer using the economic evaluation methodology set out in section 6.5.
- 6.3.2 Where a transmitter has to modify a transmitter-owned connection facility to meet a load customer's needs, the transmitter shall require the load customer to make a capital contribution to cover the cost of the modification. A capital contribution may only be required to the extent that the cost of the modification to the connection facility is not recoverable in connection rate revenues. To that end, the transmitter shall include in the economic evaluation the relevant annual connection rate revenues over the applicable economic evaluation period that are derived from that part of the customer's new load that exceeds the total normal supply capacity of any connection facility already serving the customer and that will be served by the modified connection facility. The transmitter shall calculate any capital contribution to be made by the load customer using the economic evaluation methodology set out in section 6.5.
- 6.3.3 Except where a transmitter has to modify a transmitter-owned connection facility to meet the needs of one or more generation customers or is required to construct an enabler facility, the transmitter shall require a generator customer to provide its own dedicated connection facilities and any equipment for monitoring and testing that is required by the transmitter to be installed on the customer side of the connection with the transmitter's transmission system.

- 6.3.4 Where a transmitter has to modify a transmitter-owned connection facility to meet the needs of one or more generator customers or is required to construct an enabler facility, the transmitter shall require the applicable generator customer or customers to make a capital contribution to cover the cost of the modified connection facility or of the enabler facility, calculated in accordance with the economic evaluation methodology set out in section 6.5.
- 6.3.5 A transmitter shall not require any customer to make a capital contribution for the construction of or modifications to the transmitter's network facilities that may be required to accommodate a new or modified connection. If exceptional circumstances exist so as to reasonably require a customer to make a capital contribution for network construction or modifications, the transmitter or any other interested person may apply to the Board for direction. A transmitter:
- (a) shall notify the customer as soon as possible of the transmitter's intention to apply to the Board for direction under this section 6.3.5; and
 - (b) shall not, without the prior written consent of the customer, refuse to commence or diligently pursue construction of or modifications to its network facilities pending direction from the Board under this section 6.3.5 provided that the customer has provided a security deposit to the transmitter in accordance with section 6.3.10. Where the customer requests that the transmitter not commence with construction pending direction from the Board, the transmitter shall promptly return to the customer any outstanding security deposit related to the construction.
- 6.3.6 Note: Section 6.3.6 revoked by amendment, effective August 26, 2013.
- 6.3.7 A transmitter shall provide connection facilities that have a capacity sufficient to meet the needs of the applicable customer, subject to facilities standards and good utility practice.
- 6.3.8 A transmitter shall not require a customer to make a capital contribution for capacity added by the transmitter to a transmitter-owned connection facility in anticipation of future load growth not attributable to that customer or in anticipation of the future capacity requirements of other generator customers. For this purpose, where the transmitter-owned connection facility is an enabler facility, the capacity requirements of the renewable generation

facilities expected to connect to the enabler facility shall not be considered as future capacity requirements.

6.3.9 Where a transmitter is, at the time at which it is constructing a connection facility for a customer, aware of another future customer that will need capacity within five years of the construction of the connection facility, the transmitter shall add that capacity to the connection facility at the time of construction, provided that it obtains a security deposit in a form referred to in section 6.3.11 from that future customer to cover the cost of that additional capacity. The amount of the capital contribution to be obtained from the current customer and the amount or value of the security deposit to be collected from the future customer shall be determined using the economic evaluation methodology set out in section 6.5, the load forecasts of both customers and the methodology for attributing that capital contribution as described in section 6.3.14, 6.3.14A, 6.3.15 or 6.3.16. At the time of connection of the future customer's facilities, the transmitter shall where required redo the original economic evaluation using the same inputs except for any revised load forecast provided by the future customer. This will determine the amount of capital contribution to be collected from the future customer. Where the security deposit is in the form of cash, the transmitter shall return the security deposit to the future customer at the time of connection of its facilities to the connection facility, together with interest at the rate referred to in section 6.3.11, less the amount of the future customer's capital contribution. Where the security deposit is in a form other than cash, the transmitter shall return the security deposit to the future customer upon receipt of the customer's capital contribution.

6.3.10 Where a transmitter needs to construct new or modified network or connection facilities as a result of a connection application from a customer, the transmitter may require a reasonable security deposit in a form referred to in section 6.3.11 from the customer, taking into account the size of the new load or generator output, as the case may be. Where the security deposit is in the form of cash, the transmitter shall return the security deposit to the customer, together with interest at the rate referred to in section 6.3.11, less the amount of any capital contribution owed by the customer, once the customer's facilities are connected to the transmitter's transmission facilities. Where the security deposit is in a form other than cash, the transmitter shall return the security deposit to the customer once the

customer's facilities are connected to the transmitter's transmission facilities and any capital contribution has been paid.

6.3.10A Despite section 6.3.10, a transmitter shall not require a security deposit in relation to the construction of an enabler facility.

6.3.11 A transmitter shall establish a security deposit procedure in its connection procedures referred to in section 6.1.4. The security deposit procedure shall include the following:

(a) provisions that allow a customer to provide the security deposit in the form of cash, letter of credit or surety bond, as may be selected by the customer, or such other form as the customer and the transmitter may agree;

(b) provisions stipulating that any interest to be paid by the transmitter upon returning a security deposit that is in the form of cash shall be paid at the following rates:

- i. for the period between the date on which the security deposit was provided by the customer and the date on which the security deposit is required to be returned by the transmitter, at the average over the period of the prime lending rate set by the Bank of Canada less two percent; and
- ii. for the period after the date on which the security deposit is required to be returned by the transmitter, at the prime lending rate set by the Bank of Canada plus two percent; and

(c) a description of the circumstances under which the transmitter may keep all or part of a security deposit. A transmitter shall be entitled to keep all or a part of a security deposit that has been given in relation to the construction or modification of connection or network facilities where the customer subsequently fails to connect its facilities to the transmitter's new or modified facilities. A transmitter shall not otherwise retain a security deposit given in relation to the construction or modification of network facilities unless the Board has first determined under section 6.3.5 that exceptional circumstances exist so as to reasonably require the customer to make a capital contribution for the construction or modification of network facilities.

- 6.3.12 Subject to section 6.3.18, for a single generator customer, a transmitter shall attribute to that generator customer the cost of any required modification to a transmitter-owned connection facility required to serve the rated peak output of the generation facilities.
- 6.3.13 Subject to section 6.3.18, for a single load customer, a transmitter shall attribute to that load customer the cost of any new transmitter-owned connection facility or any modification to such connection facility required to serve that part of the customer's new load that exceeds the total normal supply capacity of any connection facility already serving that customer, as reasonably projected by the load forecast provided by the load customer or by such modified load forecast as may be agreed by the load customer and the transmitter.
- 6.3.14 Subject to section 6.3.18, where more than one generator customer triggers the need for a modification to a transmitter-owned connection facility, a transmitter shall attribute the cost of the modification to those generator customers:
- (a) in accordance with such methodology as may be agreed between the transmitter and all such generator customers; or
 - (b) failing such agreement, in proportion to the rated peak output of their respective generation facilities and, in the case of line connection facilities, taking into account the length of line used by each generator customer in proportion to the length of line being shared by the customers.
- 6.3.14A Where a transmitter is required to construct an enabler facility, the transmitter shall attribute the cost of the enabler facility, depreciated to the time of connection, to generator customers connecting to the enabler facility from time to time in proportion to the manufacturer's total installed rated capacity of their respective generation facilities at the time of connection expressed as a percentage of the total capacity of the enabler facility. For this purpose, the total capacity of the enabler facility shall be determined on the basis of its capacity at the time at which the enabler facility comes into service.
- 6.3.15 Subject to section 6.3.18, where more than one load customer triggers the need for a new or modified transmitter-owned connection facility, a

transmitter shall attribute the cost to those load customers:

- (a) in accordance with such methodology as may be agreed between the transmitter and all such load customers; or
- (b) failing such agreement, in proportion to their respective non-coincident incremental peak load requirements, as reasonably projected by the load forecasts provided by each such load customer or by such modified load forecast as may be agreed by such load customer and the transmitter and, in the case of line connection facilities, taking into account the length of line used by each load customer in proportion to the length of line being shared by the customers.

6.3.16 Subject to section 6.3.18, for a new or modified transmitter-owned connection facility that will serve a mix of load customers and generator customers, a transmitter shall attribute the cost of the new connection facility or modification to those customers based on their proportional benefit, which the transmitter shall determine by considering such factors as the incremental rated peak output of each generation facility, the non-coincident incremental peak load requirements of each load customer, and the length of line used by each customer in proportion to the length of line being shared by the customers.

6.3.16A Despite section 6.3.16:

- (a) a transmitter shall not attribute the cost of an enabler facility to a load customer that connects to the enabler facility unless section 6.3.2 applies; and
- (b) a transmitter shall attribute the cost of an enabler facility to generator customers in accordance with section 6.3.14A.

6.3.17 Where a customer has made a capital contribution for the construction or modification of a transmitter-owned connection facility other than an enabler facility, and where that capital contribution includes the cost of capacity on the connection facility in excess of the customer's needs, the transmitter shall provide a refund, calculated in accordance with section 6.3.17A, to the customer as follows:

- (a) where the customer made the capital contribution before August 26, 2013, the refund shall be provided if that excess capacity is assigned to another customer within five years of the date on which the connection facility or modification to the connection facility comes into service; or
- (b) where the customer makes the capital contribution on or after August 26, 2013, the refund shall be provided if that excess capacity is assigned to another customer within fifteen years after the date on which the connection facility or modification to the connection facility comes into service.

Where such a refund is required, the transmitter shall require a financial contribution from the subsequent customer to cover the amount of that refund.

6.3.17A For the purposes of section 6.3.17, the transmitter shall determine the amount of:

- (a) the refund to the initial customer from the subsequent customer by calculating a revised capital contribution amount using the prescribed economic evaluation methodology set out in section 6.5 and the same inputs as used in the original economic evaluation except for load (which will be based on the actual load of the initial customer up to the time of connection of the subsequent customer and a revised load forecast for the remainder of the economic evaluation period) and revised attributed cost (which will be determined using the methodology set out in section 6.3.14, 6.3.15 or 6.3.16, as applicable); and
- (b) the financial contribution from the subsequent customer by calculating a capital contribution amount using the prescribed economic evaluation methodology set out in section 6.5 and the same inputs as used in the original economic evaluation except for load (which will be based on the subsequent customer's load forecast for the remainder of the economic evaluation period) and attributed cost (which will be determined using the methodology set out in section 6.3.14, 6.3.15 or 6.3.16, as applicable).

6.3.18 Where one or more customers triggers the need for a new or modified transmitter-owned connection facility and the IESO undertakes an assessment at the request of a transmitter that confirms the new or modified connection facility will also address a broader network system need, the

transmitter shall determine the proportional benefit and the related attribution of costs between the triggering customer(s), collectively, and the network pool. The transmitter shall then attribute the collective triggering customer costs to each triggering customer(s) in accordance with the methodology set out in section 6.3.12, 6.3.13, 6.3.14, 6.3.15 or 6.3.16, as applicable.

6.3.18A Where section 6.3.18 applies, the transmitter shall apply to the Board for approval of the attribution of costs between the triggering customer(s) and the network pool. Where the Board approves a different attribution of costs, the transmitter shall recalculate the capital contribution to be made by the triggering customer(s).

6.3.19 Where a distributor is required under this Code to provide a capital contribution to a transmitter, the transmitter shall permit the capital contribution to be provided in equal installments over a period of time not to exceed five years unless a longer period is approved by the Board. Where a distributor provides the capital contribution in installments, the transmitter shall charge interest on the unpaid balance at the Board's prescribed construction work in progress (CWIP) rate which is updated quarterly and published on the Board's website. The interest charges shall accrue monthly commencing on the date the connection asset goes into service and be paid annually, as part of each installment payment.

6.3.20 For the purposes of section 3.6.1 of the Distribution System Code, the transmitter shall, upon the request of a transmission-connected distributor, calculate the capital contribution amount for each distributor and each distribution-connected large load customer with a non-coincident peak demand exceeding 5 MW that contributes to the need for a new or modified transmitter-owned connection facility using the methodology and inputs described in Appendix 5 of this Code. The transmitter shall calculate any true-ups in respect of each capital contribution in accordance with the true-up provisions of section 6.5.

6.4 CUSTOMER IMPACT ASSESSMENTS

6.4.1 A transmitter shall establish in its connection procedures referred to in section 6.1.4 a customer impact assessment procedure to be used to assess

the impact of proposed new or modified connections on existing customers. The transmitter shall use best efforts to coordinate its customer impact assessment procedure with the Market Rules and the IESO's market procedures as they relate to connection assessments and approvals.

- 6.4.2 A CIA shall indicate existing available fault current levels and any change in those levels expected to be caused by a proposed new or modified connection, for each affected customer.
- 6.4.3 A transmitter shall carry out a CIA for any proposed new or modified connection where:
- (a) the connection is one for which the IESO's connection assessment and approval process requires a system impact assessment; or
 - (b) the transmitter determines that the connection may have an impact on existing customers.

Where the transmitter decides not to carry out a CIA for any proposed new connection or modification that is not subject to the a system impact assessment, the transmitter shall notify existing customers in the vicinity, advising them of the proposed new connection or modification and of the transmitter's decision not to carry out a CIA on the basis that no customer impact is expected.

- 6.4.4 A transmitter shall use the results of a CIA to provide each customer affected by a proposed new or modified connection with a new available fault current level in order to allow each customer to take, at its own expense, action to upgrade its facilities as may be required to accommodate the new available fault current level up to the maximum allowable fault levels set out in Appendix 2.
- 6.4.5 A transmitter shall provide a copy of a CIA to each customer whose facilities are located in the study area used for conducting the CIA and to the Ontario Electrical Safety Authority. A transmitter shall also provide a copy of a CIA to the IESO where the proposed new or modified connection that is the subject of the CIA was the subject of a system impact assessment by the IESO.

6.5 ECONOMIC EVALUATION OF NEW AND MODIFIED CONNECTIONS

GENERATOR CUSTOMERS

6.5.1 Where a transmitter modifies a transmitter-owned connection facility to meet the needs of a generator customer, the transmitter shall require the generator customer to pay the fully allocated cost of the minimum design required to meet the customer's needs. The transmitter shall include the capital cost of equipment installed on transmitter-owned connection facilities by the transmitter for monitoring the performance of the generation facility and for verification testing of fault protection equipment associated with the generation facility. If the generator customer elects to have verification testing costs included in the economic evaluation rather than paying such costs on an "as incurred" basis over time, the transmitter shall also include the present value of the estimated cost of doing periodic verification testing of its monitoring and testing equipment and, if necessary, of similar equipment owned by the generator customer. The transmitter shall not include costs associated with incremental operation and maintenance.

6.5.1A Where a transmitter constructs an enabler facility, the cost to be attributed to generator customers under section 6.3.14A shall be the fully allocated cost of the enabler facility. The transmitter shall include the capital cost of equipment installed on transmitter-owned connection facilities by the transmitter for monitoring the performance of the generation facilities and for verification testing of fault protection equipment associated with the generation facilities. If any generator customer elects to have verification testing costs included in the economic evaluation rather than paying such costs on an "as incurred" basis over time, the transmitter shall also include the present value of the estimated cost of doing periodic verification testing of its monitoring and testing equipment and, if necessary, of similar equipment owned by the generator customer. The transmitter shall include the present value of the operation and maintenance costs associated with an enabler facility.

LOAD CUSTOMERS

6.5.2 A transmitter shall establish in its connection procedures referred to in section 6.1.4 and implement an economic evaluation procedure that sets out how the transmitter will carry out an economic evaluation of a proposed new

or modified connection of a load customer to determine what capital contribution is to be made by the load customer. The economic evaluation procedure shall:

- (a) include the methodology that will be used by the transmitter in determining the financial risk associated with a proposed connection of a load customer, which methodology shall meet the requirements of and be consistent with Appendix 4;
- (b) provide that the economic evaluation period will be 5 years for a high risk connection, 10 years for a medium-high risk connection, 15 years for a medium-low risk connection, and 25 years for a low risk connection;
- (c) be based on the discounted cash flow calculation set out in Appendix 5 using the forecast connection rate revenues from the connection facilities and the fully allocated capital cost, operating and maintenance cost and administrative cost of the minimum design required to meet the customer's needs. The costs shall include the transmitter's cost of transmitter-owned equipment for monitoring and testing installed on connection facilities on either side of the connection point, and the cost of carrying out verification testing on that equipment;
- (d) establish that the cost used in the economic evaluation is limited to the advancement costs where the transmitter had planned a new or modified connection facility and moves the planned date forward to accommodate a customer;
- (e) use a discount rate that is based on the transmitter's current deemed debt-to-equity ratio, debt and preference share costs and Board-approved rate of return on equity;
- (f) require that discounting reflect the true timing of expenditures so that up-front capital expenditures are treated as occurring at the beginning of the first year of operation, and future capital expenditures, annual connection rate revenues and average operation and maintenance costs will be treated as occurring at the mid-point of the year in which they occur;
- (g) take into account all relevant tax amounts, adjusted by any applicable capital cost allowance;
- (h) exclude network facility costs and network rate revenues;
- (i) exclude historic revenues and sunk costs;

- (j) establish that the relevant connection rate revenues shall be the revenue derived from that part of the load customer's new load that exceeds the total normal supply capacity of any connection facility already serving that customer and which will be served by a new or modified connection facility;
- (k) require that the customer provide its load shape in such form and detail as the transmitter may reasonably require; and
- (l) provide for separate economic evaluations for transformation connection facilities and line connection facilities.

The economic evaluation procedure may permit an initial calculation of a customer's capital contribution based on estimated costs, provided that where this occurs the transmitter must subsequently recalculate the customer's capital contribution in accordance with paragraph (c) based on actual costs as soon as these are known, and obtain from or credit the customer for any difference between the two calculations. Such recalculated capital contribution shall thereafter be used as the customer's capital contribution for all purposes under this Code.

Economic evaluation true-up calculations for load customers

- 6.5.3 For new or modified connection facilities, a transmitter shall carry out a true-up calculation, based on actual customer load, at the following true-up points:
- (a) for high risk connections, at the end of each year of operation, for five years;
 - (b) for medium-high risk and medium-low risk connections, at the end of each of the third, fifth and tenth year of operation; and
 - (c) for low risk connections, at the end of each of the fifth and tenth year of operation, and at the end of the fifteenth year of operation if actual load is 20 percent higher or lower than the initial load forecast at the end of the tenth year of operation.
- 6.5.4 Subject to sections 6.5.8, 6.5.9 and 6.5.10, for the true-up calculation, a transmitter shall use the same methodology used to carry out the initial economic evaluation, and the same inputs except for load, which will be based on the actual load up to the true-up point and an updated load forecast for the remainder of the economic evaluation period used.

- 6.5.5 Subject to sections 6.5.8, 6.5.9 and 6.5.10, before carrying out a true-up calculation for a load customer who did not make an initial capital contribution, a transmitter shall adjust the initial load forecast used in the initial economic evaluation to the point where the present value of connection rate revenues equals the present value of costs.
- 6.5.6 Where a true-up calculation shows that a load customer's actual load and updated load forecast is lower than the load in the initial load forecast, and does not generate the initial forecast connection rate revenues, a transmitter shall require the load customer to make a payment to make up the shortfall, adjusted appropriately to reflect the time value of money.
- 6.5.7 Where a true-up calculation shows that a load customer's actual load and updated load forecast is higher than the load in the initial load forecast, and generates more than the initial forecast connection rate revenues, the transmitter shall post the excess revenue as a credit to the customer in a notional account. The transmitter shall apply this credit against any shortfall in subsequent true-up calculations. The transmitter shall rebate to the load customer any credit balance that remains when the last true-up calculation is carried out, adjusted appropriately to reflect the time value of money. The rebate shall not exceed any capital contribution, adjusted to reflect the time value of money, previously paid by the load customer.
- 6.5.8 When carrying out a true-up calculation for a distributor, a transmitter:
- (a) shall add to the actual load the amount of any embedded generation (determined in accordance with section 11.1) that was installed during the true-up period; and
 - (b) shall not reduce the updated load forecast as a result of any embedded generation (determined in accordance with section 11.1) that was installed during the true-up period.

- 6.5.9 When carrying out a true-up calculation for a load customer other than a distributor, a transmitter:
- (a) shall add to the actual load the amount of any embedded generation (determined in accordance with section 11.1) of 1 MW or less per unit, or any embedded renewable generation of 2 MW or less per unit, that was installed during the true-up period; and
 - (b) shall not reduce the updated load forecast as a result of any embedded generation (determined in accordance with section 11.1) of 1MW or less per unit, or any embedded renewable generation of 2 MW or less per unit, that was installed during the true-up period.
- 6.5.10 When carrying out a true-up calculation for any load customer, a transmitter:
- (a) shall add to the actual load the amount of any reduction in the customer's load that the customer has demonstrated to the reasonable satisfaction of the transmitter (such as by means of an energy study or audit) has resulted from energy conservation, energy efficiency, load management or renewable energy activities that occurred during the true-up period; and
 - (b) shall not reduce the updated load forecast as a result of any reduction in the customer's load that the customer has demonstrated to the reasonable satisfaction of the transmitter (such as by means of an energy study or audit) has resulted from energy conservation, energy efficiency, load management or renewable energy activities that occurred during the true-up period.
- 6.5.11 Where a load customer voluntarily and permanently disconnects its facilities from a transmitter's facilities prior to the last true-up point referred to in section 6.5.3, the transmitter shall at the time of disconnection carry out a final true-up calculation in accordance with the rules set out in sections 6.5.4, 6.5.5, 6.5.8 and 6.5.9. Where the true-up calculation shows that the load customer's load to the date of disconnection has not generated the initial forecast connection rate revenues, the transmitter shall require the load customer to make a payment to make up the shortfall, adjusted appropriately to reflect the time value of money. Where a true-up calculation shows that the load customer's load to the date of disconnection has generated more than the initial forecast connection rate revenues, the transmitter shall rebate to the load customer any excess, adjusted appropriately to reflect the time

value of money. The rebate shall not exceed any capital contribution, adjusted to reflect the time value of money, previously paid by the load customer.

6.6 CONTESTABILITY

- 6.6.1 Where a load customer requires new connection facilities, a transmitter shall allow the load customer to elect either to provide its own connection facilities or to require the transmitter to provide them. Where the load customer elects to require the transmitter to provide the connection facilities, the transmitter shall also allow the load customer to elect to have any associated contestable construction or design work (as identified in the transmitter's contestability procedure referred to in section 6.6.2) carried out by a party other than the transmitter.
- 6.6.2 A transmitter shall establish in its connection procedures referred to in section 6.1.4 and implement a contestability procedure. The contestability procedure shall establish:
- (a) what work can be done by the transmitter only, on its own existing facilities, including conceptual design (uncontestable work), and what other connection facility construction and design work may, at a load customer's option, be done by either the transmitter or the load customer (contestable work), provided that if the load customer intends or is required to transfer any connection facilities that it constructs to the transmitter, design work required to establish the transmitter's technical requirements and specifications in relation to a given connection project shall be uncontestable;
 - (b) the obligation of the transmitter to provide, at no cost:
 - i. a description of the contestable work and uncontestable work;
 - ii. a description of the labour and materials for each of the contestable work and the uncontestable work;
 - iii. an initial estimate of the capital cost for each of the contestable work and the uncontestable work, broken down into labour (including design, engineering and construction), materials, equipment, direct overhead (including administration) and

indirect overhead costs, together with an indication of the degree of accuracy of that estimate;

- iv. the calculation used to determine any capital contribution to be paid by the load customer if the transmitter constructs the connection facilities, even if no capital contribution is required. This calculation must include all of the assumptions and inputs used to produce the economic evaluation as described in section 6.5, including the manner in which the customer's risk classification has been determined under Appendix 4; and
- v. the information set out in Appendix 3, and the technical standards and specifications applicable to the contestable work, in sufficient detail to allow the load customer to design and construct connection facilities that will meet the requirements applicable to the transmitter's transmission system;

and to provide, at cost, any revisions to this information required either due to changes in the load customer's plans or to obtain additional design work in order to enhance the transmitter's initial capital cost estimate;

- (c) the right of a load customer to choose to carry out the contestable work or to require the transmitter to do it, provided that where the load customer chooses to carry out the contestable work, it must carry out all of the contestable work;
- (d) where a load customer elects to carry out contestable work, the obligation of the load customer to complete that contestable work in accordance with the transmitter's conceptual design and technical standards and specifications and to pay any Board-approved fees for inspection, testing and commissioning by the transmitter;
- (e) the right of a load customer to transfer any dedicated connection facilities it constructs to the transmitter and the obligation of a load customer to transfer non-dedicated connection facilities that it constructs to the transmitter;
- (f) where a load customer proposes or is obliged to transfer any connection facilities it constructs to the transmitter, the obligation of the transmitter to provide, upon request and at cost, engineering design in sufficient detail to allow the load customer to carry out the contestable work and meet the

specific connection facility design and performance requirements of the transmitter;

- (g) the obligation of the transmitter to pay a transfer price that is the lower of the cost to the load customer or the transmitter's reasonable cost to do the same work, for any connection facility a load customer constructs and opts or is required to transfer to the transmitter; and
- (h) where the transmitter pays a transfer price for a connection facility constructed by a load customer, the obligation of the transmitter to make any adjustment required to reflect that transfer price in any capital contribution that is to be paid by the load customer.

The transmitter shall prepare all estimates required by this section 6.6.2 in accordance with good utility practice and industry standards.

6.6.3 A transmitter shall provide a copy of its contestability procedure to any load customer requiring new connection facilities.

6.7 REPLACEMENT AND RELOCATION OF EXISTING CONNECTION FACILITIES

6.7.1 A transmitter shall notify each customer that will be affected by the transmitter's plans to retire a connection facility, at least five years in advance of the effective date of the retirement. The transmitter shall give each affected customer the option of:

- (a) providing its own replacement connection facility;
- (b) connecting its facilities to the connection facility of another person; or
- (c) requiring the transmitter to provide a replacement connection facility.

6.7.2 Where a transmitter-owned connection facility has reached its end-of-life and is planned to be retired and replacement with a new connection facility is determined to be the optimal solution, the transmitter shall undertake an assessment, in consultation with any affected customers, to determine the appropriate capacity of the replacement connection facility. Where the asset is replaced, the transmitter shall either:

- (a) not recover a capital contribution from a customer to replace that connection facility, where the new facility is the same capacity or lower

capacity; or

- (b) recover a capital contribution from a customer to replace the connection facility, where the customer requires additional capacity. The capital contribution shall be limited to the incremental cost relative to the cost of a like-for-like replacement facility.

6.7.2A Where a transmitter-owned connection facility has not reached its end-of-life and is replaced at the request of a customer, the transmitter shall recover a capital contribution from the customer. The capital contribution shall be equal to the remaining net book value of the replaced asset plus the advancement cost.

6.7.3 Where a customer requests the relocation of a transmitter's connection or network facility, the transmitter shall recover from that customer the cost of relocating that connection or network facility.

6.7.4 Where a transmitter's connection or network facility is relocated in the absence of a customer request, the transmitter shall bear the cost of relocating that connection or network facility.

6.8 OBLIGATIONS BETWEEN NEIGHBOURING ONTARIO TRANSMITTERS

6.8.1 A transmitter shall enter into an agreement with each neighbouring Ontario transmitter. The agreement shall describe the facilities connecting the two transmission systems and shall set out the respective obligations of the parties in relation to:

- (a) transmission system expansion and associated cost responsibilities;
- (b) operational requirements and authorities;
- (c) protections;
- (d) emergency preparedness and emergency operations;
- (e) outage co-ordination;
- (f) forced outages;
- (g) new or modified transmission facilities;
- (h) the information to be exchanged between the parties;

- (i) the protection of confidential information; and
- (j) a dispute resolution process that provides for the fair, timely and effective resolution of disputes and that sets out specific timelines for completion of the dispute resolution process.

6.8.2 An agreement referred to in section 6.8.1 shall contain such other provisions as may be required to enable a transmitter to comply with its obligations under this Code relative to neighbouring Ontario transmitters and to the reliability and integrity of its transmission system.

6.8.3 Where a transmitter had an executed agreement with a neighbouring Ontario transmitter on August 26, 2013, the parties shall amend that agreement as may be required to ensure that it complies with the requirements of sections 6.8.1 and 6.8.2. Such amendment shall be made as soon as any other amendment to the agreement is being made by the parties and in any event no later than August 26, 2018.

6.9 RECORD KEEPING AND REPORTING REQUIREMENTS

6.9.1 A transmitter shall maintain complete and accurate records of all economic evaluations required to be carried out under this Code, including the economic evaluations referred to in sections 6.3.9 and 6.3.17A. Each record must show the details of the economic evaluation, including the determination of the risk classification and the resulting economic evaluation period, the load forecast, the project capital costs, the ongoing operation and maintenance costs, and the project after tax incremental cost of capital, and must include the justification for all of the study parameters.

6.9.2 A transmitter shall file the records referred to in section 6.9.1 with the Board on request.

6.10 RECONNECTION

6.10.1 A transmitter shall investigate and determine the cause of any reported shutdown of a customer's facilities, regardless of the reason for that shutdown, using available evidence including input from the customer's staff.

The transmitter shall upon request provide the customer with the results of its investigation.

- 6.10.2 Once a transmitter is satisfied that reconnection of a customer's facilities will not cause any adverse effects on the transmitter's transmission system, it shall as soon as practicable, advise the customer when reconnection can take place. Reconnection to the transmitter's transmission facilities shall not take place until authorized by the transmitter.
- 6.10.3 A transmitter shall establish a reconnection procedure in its connection procedures referred to in section 6.1.4 setting out the steps to be taken by the transmitter when a customer whose facilities have been disconnected asks to be reconnected. The procedure shall also provide for notice to be given to the customer, setting out all steps to be taken by the customer and the transmitter, any system studies that will be carried out by the transmitter, any cost to be borne by the customer, and the duration of the reconnection process.
- 6.10.4 A transmitter shall not carry out a system study in relation to a proposed reconnection unless it can demonstrate that the system study is necessary to ensure system integrity or is required by the IESO.

7. COMPLIANCE, INSPECTION, TESTING AND MONITORING

7.1 REQUIREMENTS

- 7.1.1 A transmitter shall inspect, test and monitor its transmission facilities to ensure continued compliance with all applicable standards and instruments referred to in section 5.1.2.
- 7.1.2 A transmitter shall maintain complete and accurate records of the results of all performance inspecting, testing and monitoring that it conducts in fulfillment of its obligations under this Code. The transmitter shall keep these records for a minimum of seven years or for such shorter time as the Board may permit, and shall make them available to the Board on request.

8. GENERAL TECHNICAL REQUIREMENTS

8.1 INTENTIONALLY LEFT BLANK

8.2 PROTECTION AND CONTROL

8.2.1 A transmitter shall install and maintain protection systems that are capable of minimizing the severity and extent of disturbances to the transmission system while themselves experiencing a first order single contingency such as the failure of a relay protection system to operate or the failure of a breaker to trip. In particular:

- (a) the facilities designated by the transmitter or the IESO as essential to system reliability and security shall be protected by two protection systems. Each system shall be independently capable of detecting and isolating all faults on those facilities. Those facilities shall also have breaker failure protection, but breaker failure protection need not be duplicated. Both protection systems shall initiate breaker failure protection;
- (b) to reduce the risk of both protection systems being disabled simultaneously by a single contingency, the two protection systems shall not use common components;
- (c) the use of two identical protection systems should be avoided to reduce the risk of simultaneous failure of both systems due to design deficiencies or facilities problems;
- (d) the protection systems shall be designed to isolate only the faulted facilities. For faults outside the protected zone, each protection system shall be designed either not to operate or to operate selectively in coordination with other protection systems;
- (e) protection settings at tapped transformer stations owned by the transmitter, for protection of system elements affected by conditions on the transmission system, shall be coordinated with other system elements of the transmission system;
- (f) protection systems shall not operate to trip for stable power swings following contingencies that are judged by protection system designers as not harmful to the transmission system or its customers;

- (g) the components and software used in all protection systems shall be of proven quality for effective utility application and follow good utility practice;
- (h) critical features associated with the operability of protection systems and the high voltage interrupting device (HVI) shall be annunciated or monitored;
- (i) the design of protection systems shall facilitate periodic testing and maintenance. Test facilities and procedures shall not compromise the independence of the redundant protection systems. Test switches shall be used to eliminate the need to disconnect wires during testing;
- (j) the two protection systems shall be supplied from separate secondary windings of a voltage and current transformer or from separate voltage and current transformers; and
- (k) protection system circuitry and physical arrangements shall be designed to minimize the possibility of incorrect operations from personnel error.

8.2.2 A transmitter shall follow the specific protection and control practices and facilities requirements which are set out in Schedule G of the applicable version of the connection agreement set out in Appendix 1.

8.2.3 A transmitter should apply protection systems using the typical tripping matrix for transmission system protection shown in Exhibit E.2, Schedule E of the applicable version of the connection agreement set out in Appendix 1.

8.3 INSULATION COORDINATION

- 8.3.1 A transmitter shall ensure that its facilities are protected against lightning and switching surges. This shall include station shielding against direct lightning strokes, surge protection on all wound devices, and cable/overhead interfaces.
- 8.3.2 A transmitter shall ensure that a tap connected to a shielded transmission circuit is also shielded.

8.4 GROUNDING

- 8.4.1 A transmitter shall ensure that grounding installations are capable of carrying the maximum foreseeable fault current, for the duration of such fault currents, without risking safety to personnel that may be present on site when a fault, damage to facilities, or interference with the operation of the transmission system occurs.
- 8.4.2 A transmitter shall ensure that each of its tapped transformer stations and network transformation and switching stations has a ground grid to which all metallic structures, metallic equipment and non energized metallic equipment are solidly connected. The size, type and requirements for the ground grid are site specific, depending on such factors as soil conditions, station size, and short circuit level.

9. TECHNICAL REQUIREMENTS FOR TAPPED TRANSFORMER STATIONS SUPPLYING LOAD

9.1 SUPPLY CONSIDERATIONS

- 9.1.1 A transmitter shall ensure that tapped transformer stations, excluding those that are deemed compliant under section 4.6 of this Code, have adequate on load tap changer or other voltage regulating facilities to operate continuously within normal variations on the transmission system as set out in the Market Rules and to operate in emergencies with a further transmission system voltage variation of six percent.
- 9.1.2 A transmitter shall ensure that the grounding of power transformer windings at tapped transmission system stations do not adversely affect the reliability of the transmission system.

9.2 PROTECTION REQUIREMENTS

- 9.2.1 A transmitter's protection and teleprotection requirements will be identified in the connection agreement. These requirements apply to the facilities that interface between the customer and the transmitter systems. Typical technical requirements are set out in Exhibit E.1, Schedule E of the applicable version of the connection agreement set out in Appendix 1, and Exhibits F.1 and F.2, Schedule F of version A of the connection agreement set out in Appendix 1.
- 9.2.2 Intentionally left blank.
- 9.2.3 Intentionally left blank.
- 9.2.4 Intentionally left blank.
- 9.2.5 Intentionally left blank.
- 9.2.6 Where remote/transfer trip circuits are used for tapped transformer faults to trip the transmitter's line breakers at the terminal stations, the tapped transformer shall be equipped with a motor operated transformer disconnect switch at that station to provide a point of separation from the transmission

system. Energization of remote/transfer trip and opening of the disconnect switch (89) shall be initiated simultaneously from the protection circuits. Full opening of the disconnect switch shall block sending of remote trip.

10. PROTECTION SYSTEM REQUIREMENTS

10.1 TELECOMMUNICATIONS

10.1.1 A transmitter shall ensure that telecommunication facilities used for protection purposes have a level of reliability consistent with the required performance of the protection system.

10.1.2 A transmitter shall specify to all customers telecommunication channel media and protective systems in the connection agreement. These requirements shall apply to the facilities that interface between the customer and the transmitter systems.

10.1.3 A transmitter shall ensure that telecommunication circuits used for the protection and control of the transmission system are dedicated to that purpose.

10.1.4 Intentionally left blank.

10.1.5 A transmitter shall ensure that telecommunication systems are:

- (a) designed to prevent unwanted operations such as those caused by equipment or personnel,
- (b) powered by the station's batteries or other sources independent from the power system, and
- (c) monitored in order to assess equipment and channel readiness.

10.1.6 A transmitter shall include a maximum annual specification on major disturbances cause by telecommunication failures in the connection agreement.

10.1.7 A transmitter shall include a maximum annual specification for unavailability of the telecommunication protection for a single transmission system circuit and for two circuits in the connection agreement.

10.1.8 A transmitter shall include a maximum annual specification for telecommunication false trip rate in the connection agreement.

10.1.9 A transmitter shall include a maximum annual specification in the connection

agreement for total transmission system circuit trips coincident with the telecommunications failure.

10.2 TEST SCHEDULE FOR RELAYING COMMUNICATION CHANNELS

10.2.1 A transmitter shall test communication channels associated with protective relaying at periodic intervals to verify that the channels are operational and that their characteristics are within specific tolerances. Testing should include signal adequacy tests and channel performance tests.

10.3 VERIFICATION AND MAINTENANCE PRACTICES

10.3.1 A transmitter shall establish verification intervals for protection systems not otherwise covered by the requirements of a reliability organization. Verification is required after any change is made to an existing protection system.

10.4 FUNCTIONAL TESTS AND PERIODIC VERIFICATION

10.4.1 For direct current circuitry checks, a transmitter shall thoroughly check the logic of the transmitter's auxiliary circuitry with the direct current applied and the initiating devices suitably energized to initiate the process. Operation or tripping of any interrupting or isolating device shall always be verified, as well as local and/or remote annunciation.

10.4.2 A transmitter shall ensure that "on potential" checks shall follow all necessary preliminary procedures. The main equipment shall be energized but not placed on load. At its tapped transformer stations, the transmitter shall check all readings of potentials, including determination of correct phasing/phase rotation. The test must also demonstrate that all equipment performs as expected when energized and is in a condition to have primary load applied.

10.4.3 At its tapped transformer stations, a transmitter shall make "On Load" checks following the application of appropriate load, voltage, current, phase angle or crossed wattmeter readings at the appropriate instrument transformer outputs or protection input points, to ensure that all quantities are appearing as required with respect to magnitude, phase relation, etc. These checks are

to determine that relays are properly connected and that the watt and var checks of all indicating and referenced equipment are correct. At times it may be necessary to repeat some or all tests, e.g. relay performance, using load currents.

10.5 FAILURE PROTECTION FOR HIGH VOLTAGE INTERRUPTING DEVICES

- 10.5.1 A transmitter shall ensure that protection is provided to trip local and remote breakers if a high voltage interrupting device (HVID) fails to clear a fault properly. The requirements for HVID failure protection vary depending on the maximum permissible fault duration and the location of the connection on the transmission system. Some portions of the transmission system are designed and operated to more stringent requirements to avoid adversely affecting neighbouring transmission systems.
- 10.5.2 If the IESO or the transmitter so determines, the HVID failure protection shall be achieved by using remote or transfer trip circuits and opening of the motor operated disconnect switch.
- 10.5.3 In portions of the transmission system having less stringent requirements, the HVID failure protection may be achieved by the opening of the motor operated disconnect switch. If the disconnect switch experiences a flashover, the line protection at the transmitter's transmission stations shall operate to isolate the fault.
- 10.5.4 A transmitter shall not use automatic ground switches for any transmitter owned new installations for triggering line protection operation.
- 10.5.5 When circuit switchers are used, the interrupter and disconnect switch shall operate independently. Protection systems that trip the interrupter shall simultaneously initiate opening of the disconnect switch.
- 10.5.6 The direct current voltage supplied to the interrupter and disconnect switch shall be fed from separately fused and monitored direct current supplies: that is, by two direct current cables to the control cabinet.

10.6 INSTRUMENT TRANSFORMERS

- 10.6.1 A transmitter shall ensure that current transformer output remains within acceptable limits for all anticipated fault currents and for all anticipated burdens connected to the current transformer.
- 10.6.2 A transmitter shall ensure that current transformers are connected so that adjacent relay protection zones overlap and, where they do not overlap, shall ensure appropriate mitigation is provided.
- 10.6.3 A transmitter shall ensure that voltage transformers and potential devices have adequate volt ampere capacity to supply the connected burden while maintaining their accuracy over the specified primary voltage range.
- 10.6.4 For each independent protection system, a transmitter shall ensure that separate current and voltage transformer or potential device secondary windings are used, except on low voltage devices.
- 10.6.5 A transmitter shall ensure that interconnected current transformer secondary wiring and voltage transformer secondaries are each grounded only at a single point.

10.7 BATTERY BANKS AND DIRECT CURRENT SUPPLY

- 10.7.1 A transmitter shall ensure that if either the battery charger fails or the AC supply source fails, the station battery bank shall have enough capacity to allow the station to operate for at least eight hours for a single battery system or at least six hours for each of the batteries in a two battery system.
- 10.7.2 A transmitter shall ensure that critical DC supplies such as relay protection circuits and high voltage interrupters (HVIs) shall be monitored and alarmed.
- 10.7.3 A transmitter shall ensure that all generating facilities connected to the transmission system have two separately protected (fuse/breaker) and monitored DC station battery systems unless the transmitter and the IESO determine otherwise.
- 10.7.4 A transmitter shall ensure that tapped transformer stations have at least one protected (fuse/breaker) monitored DC station battery system. A transmitter

may specify that two systems are required.

10.7.5 Where two battery systems are required, there shall be a battery transfer scheme.

10.7.6 Where the use of a single battery system is allowed, the following conditions shall be met:

- (a) it can be tested and maintained without removing it from service;
- (b) each protection system shall be supplied from physically separated and separately fused direct current circuits; and
- (c) no single contingency other than failure of the battery bank itself shall prevent successful tripping for a fault.

11. EMBEDDED GENERATION AND BYPASS COMPENSATION

11.1 EMBEDDED GENERATION

11.1.1 A transmitter shall, for all purposes, treat any generation facility that came into service on or before June 8, 2004 as embedded generation in relation to a load, provided that the generation facility was always connected on the customer side of the connection point. This requirement applies regardless of ownership of the generation facility, the voltage at which the generation facility is connected, the location of the generation facility, the size or number of units of generation capacity, or any relationship between the owner of the generation facility and the customer or the load.

11.1.2 A transmitter shall, for all purposes, treat any new generation facility that comes into service after June 8, 2004 as embedded generation in relation to a load, provided that the generation facility is connected on the customer side of the connection point at the time the generation facility comes into service. This requirement applies regardless of ownership of the generation facility, the voltage at which the generation facility is connected, the location of the generation facility, the size or number of units of generation capacity, or any relationship between the owner of the generation facility and the customer or the load.

11.1.3 If at any time after a generation facility comes into service it is reconfigured so as to become connected on the customer side of the point where a load facility is connected to a transmitter's transmission facilities, the transmitter shall not for any purpose treat that generation facility as embedded generation in relation to that load.

11.1.4 If at any time after a generation facility that is connected to a transmitter's transmission system comes into service a load customer disconnects its facilities from the transmitter's transmission facilities and subsequently connects its facilities, or a load facility becomes connected:

- (a) directly to the generation facility; or

- (b) to the facilities of any person such that both the load facility and the generation facility are connected to the transmitter's transmission facilities on that person's side of the connection point,
the transmitter shall not for any purpose treat that generation facility as embedded generation in relation to that load facility.

11.1.5 The reference to "for all purposes" and "for any purpose" in sections 11.1.1 to 11.1.4 includes the purpose of determining whether bypass compensation is required to be paid by the load customer and the purpose of determining the manner in which network charges will be applied.

11.2 BYPASS COMPENSATION

11.2.1 A transmitter shall require bypass compensation from a customer if:

- (a) the customer disconnects its load facility from the transmitter's connection facilities and connects that facility to a generation facility or to another load facility that is not owned by the transmitter such that both the load facility and a generation facility are connected to the transmitter's transmission facilities on that customer's side of the connection point and the transmitter will no longer receive line connection or transformation connection rate revenues in relation to that disconnected facility; or
- (b) the customer, while retaining its connection to the transmitter's transmission system, also connects its load facility to a generation facility or to another load facility that is not owned by the transmitter such that the customer reduces its load served directly by the transmitter's transmission system, and the line connection or transformation connection rate revenues in relation to that facility will be reduced.

The transmitter shall calculate bypass compensation using the methodology set out in section 11.2.6.

11.2.2 Where a transmitter becomes aware that a customer intends to bypass a transmitter-owned connection facility in the manner described in section

- 11.2.1, the transmitter shall promptly notify all other load customers served by the connection facility that is intended to be bypassed.
- 11.2.3 A transmitter shall not require bypass compensation from a customer for any reduction in a customer's load served by the transmitter's connection facilities that the customer has demonstrated to the reasonable satisfaction of the transmitter (such as by means of an energy study or audit) has resulted from embedded renewable generation (determined in accordance with section 11.1), energy conservation, energy efficiency or load management activities, except in accordance with the transmitter's Rate Order.
- 11.2.4 When a load customer provides its own connection facility to serve new load or transfers new load to the connection facility of another person, the transmitter shall not require bypass compensation from that customer.
- 11.2.5 Subject to sections 6.7.2, 11.2.6 and 11.2.7, for all or a portion of existing load a load customer may bypass a transmitter-owned connection facility with its own connection facility or the connection facility of another person, provided that the load customer compensates the transmitter.
- 11.2.6 For the purposes of sections 11.2.1 and 11.2.5, but subject to section 11.2.7, the transmitter shall calculate bypass compensation by first multiplying the net book value of the bypassed connection facility, including a salvage credit and reasonable removal and environmental remediation costs, if applicable, by the bypassed capacity on the relevant connection facility. The transmitter shall then divide the resulting figure by the total normal supply capacity of the bypassed connection facility. For purposes of this calculation:
- (a) the bypassed capacity on the relevant connection facility shall be equal to the difference between the customer's existing load on that connection facility at the time of bypass and the highest rolling three-month average of the customer's non-coincident peak demand in the twelve-month period following the date on which bypass occurred; and
 - (b) the normal supply capacity of the bypassed connection facility shall be determined by the transmitter in accordance with the Board-approved procedure referred to in section 6.2.7.

- 11.2.7 Where an economic evaluation, including an economic evaluation referred to in section 6.3.9 or 6.3.17A, was conducted by a transmitter for a load customer in relation to a connection facility on the basis of a load forecast, a transmitter shall not require bypass compensation from a customer under section 11.2.5 in relation to any load that represents that customer's contracted capacity, during the related economic evaluation period.
- 11.2.8 A transmitter should avoid overloading a connection facility above its total normal supply capacity. Where a connection facility has been overloaded, and a customer transfers the overload to its own connection facility or to the connection facility of another person, the transmitter shall not require bypass compensation from that customer.
- 11.2.9 A transmitter shall promptly notify the Board upon becoming aware that a load customer that is a distributor intends to bypass a transmitter-owned connection facility with its own connection facility or the connection facility of another person.
- 11.2.10 Where a transmitter becomes aware that a load customer intends to bypass a transmitter-owned connection facility with its own connection facility or the connection facility of another person, the transmitter shall promptly notify all other load customers served by the connection facility that is intended to be bypassed.

12. DISPUTE RESOLUTION

12.1 OBLIGATION TO INCLUDE IN PROCEDURES

12.1.1 Subject to section 12.1.4, a transmitter shall establish a dispute resolution procedure in its connection procedures referred to in section 6.1.4 and shall implement it in the event of a dispute with a customer regarding the transmitter's obligations under the Act, the Electricity Act, its license, this Code or any of the transmitter's connection procedures.

12.1.2 The dispute resolution procedure referred to in section 12.1.1 shall include provisions that:

- (a) provide for the fair, timely and effective resolution of disputes;
- (b) set out specific timelines for completion of the dispute resolution process; and
- (c) establish the right of the transmitter or the customer to bring a dispute to the Board for resolution, if it has not been resolved by the parties within 30 days.

12.1.3 If a dispute arises while a transmitter is constructing new or modified connection facilities for a customer, the transmitter shall not cease work or slow the pace of work without leave of the Board.

12.1.4 The dispute resolution procedure referred to in section 12.1.1 shall not apply to disputes that arise between a transmitter and a customer:

- (a) that are governed by the dispute resolution process contained in their connection agreement; or
- (b) that relate to the terms and conditions of a contractual arrangement that is under negotiation between the transmitter and the customer, except where one party alleges that the other party is:
 - i. seeking to impose a term or condition that is inconsistent with or contrary to the Act, the Electricity Act, a party's licence, this Code or any of the transmitter's connection procedures; or

- ii. refusing to include a term or condition that is required to give effect to this Code or any of the transmitter's connection procedures.

13. COMING INTO FORCE

13.0.1 This Code shall be in effect as of the date on which it is published in the *Ontario Gazette*, and as of that date replaces the Transmission System Code issued by the Board on August 26, 2013.

13.0.2 Except where expressly provided otherwise, any amendments to this Code shall come into force on the date on which the Board publishes the amendments by placing them on the Board's website after they have been made by the Board.